

4715.0815 JOINTS IN CHEMICAL WASTE PIPE.

Joints for chemical waste and vent piping must be of corrosion resistant material, or coated or wrapped with a corrosion resistant material, and designed for use with the type of piping material selected. All joint materials and methods must be as approved by the administrative authority.

Statutory Authority: *MS s 326.37 to 326.45; 326B.43 to 326B.49*

History: *9 SR 1557; L 2007 c 140 art 6 s 15; art 13 s 4*

Published Electronically: *May 14, 2012*