

5225.4000 BLOWOFF TANKS.

Blowoff tanks must meet the requirements of the National Board Inspection Code 27, Rules and Recommendations for the Design and Construction of Boiler Blowoff Systems.

Statutory Authority: *MS s 175.171; 183.42; 183.44; 183.465; 183.466; 183.54; 326B.958; 326B.964; 326B.966; 326B.982*

History: *13 SR 1917; 19 SR 591; L 2007 c 140 art 9 s 27; art 13 s 4*

Published Electronically: *February 19, 2009*