

7511.0701 SECTION 701, GENERAL.

IFC section 701.1 is amended by adding an exception to read:

Exception: This exception applies to the following elements that exceed the requirements for new structures or facilities: existing fire-resistance-rated construction, existing construction to resist the passage of smoke, and existing opening protectives. When approved by the fire code official: (1) maintenance of these elements is not required; and (2) removal of these elements is permitted as long as any decommissioned equipment is clearly labeled as such.

Statutory Authority: *MS s 326B.02*

History: *44 SR 610*

Published Electronically: *April 16, 2020*