SF181 REVISOR SS S0181-1 1st Engrossment

SENATE STATE OF MINNESOTA NINETY-SECOND SESSION

A bill for an act

relating to the State Building Code; clarifying exemptions from inspections for

load control allowed for electrical utilities; amending Minnesota Statutes 2020,

S.F. No. 181

(SENATE AUTHORS: RARICK and Hoffman)

1.1

1 2

1.21

1.22

DATE 01/19/2021 D-PG OFFICIAL STATUS
117 Introduction and first reading

01/19/2021 117 Introduction and first reading Referred to Labor and Industry Policy

02/04/2021 257 Author added Hoffman 03/24/2022 5581a Comm report: To pass as amended

5609 Second reading

section 326B.36, subdivision 7, by adding a subdivision. 1.4 BE IT ENACTED BY THE LEGISLATURE OF THE STATE OF MINNESOTA: 1.5 Section 1. Minnesota Statutes 2020, section 326B.36, subdivision 7, is amended to read: 1.6 Subd. 7. Exemptions from inspections. Installations, materials, or equipment shall not 1.7 be subject to inspection under sections 326B.31 to 326B.399: 1.8 (1) when owned or leased, operated and maintained by any employer whose maintenance 1.9 electricians are exempt from licensing under sections 326B.31 to 326B.399, while performing 1.10 electrical maintenance work only as defined by rule; 1.11 (2) when owned or leased, and operated and maintained by any electrical, 1.12 communications, or railway utility, cable communications company as defined in section 1.13 238.02, or telephone company as defined under section 237.01, in the exercise of its utility, 1.14 antenna, or telephone function; and 1.15 (i) are used exclusively for the generations, transformation, distribution, transmission, 1.16 load control, or metering of electric current, or the operation of railway signals, or the 1.17 transmission of intelligence, and do not have as a principal function the consumption or use 1.18 of electric current by or for the benefit of any person other than such utility, cable 1.19 communications company, or telephone company; and 1.20

(ii) are generally accessible only to employees of such utility, cable communications

company, or telephone company or persons acting under its control or direction; and

Section 1.

(iii) are not on the load side of the service point or point of entrance for communication systems;

(3) when used in the street lighting operations of an electrical utility;

2.1

2.2

2.3

2.4

2.5

2.6

2.7

2.8

2.9

2.10

2.11

2.12

2.13

2.14

2.15

2.16

2.17

2.18

2.24

2.25

2.26

- (4) when used as outdoor area lights which are owned and operated by an electrical utility and which are connected directly to its distribution system and located upon the utility's distribution poles, and which are generally accessible only to employees of such utility or persons acting under its control or direction;
- (5) when the installation, material, and equipment are in facilities subject to the jurisdiction of the federal Mine Safety and Health Act; or
- (6) when the installation, material, and equipment is part of an elevator installation for which the elevator contractor, licensed under section 326B.164, is required to obtain a permit from the authority having jurisdiction as provided by section 326B.184, and the inspection has been or will be performed by an elevator inspector certified and licensed by the department. This exemption shall apply only to installations, material, and equipment permitted or required to be connected on the load side of the disconnecting means required for elevator equipment under National Electrical Code Article 620, and elevator communications and alarm systems within the machine room, car, hoistway, or elevator lobby.
- Sec. 2. Minnesota Statutes 2020, section 326B.36, is amended by adding a subdivision to read:
- Subd. 8. Electric utility exemptions; additional requirements. For exemptions to
 inspections exclusively for load control allowed for electrical utilities under subdivision 7,
 clause (2), item (i), the following requirements apply:
 - (1) the exempted work must be conducted by a Class A electrical contractor. If a deficiency or code violation is found when conducting such work, the electrical contractor or other designee must report the deficiency or code violation to the electric utility; and
- 2.27 (2) the electric utility must, within ten calendar days of discovering the need for repair,
 2.28 inform the owner of:
- 2.29 (i) the location of the materials or equipment that need repair;
- 2.30 (ii) that a permit is required for the work; and
- 2.31 (iii) provide a time frame for the repair to be complete, not to exceed six months, after
 2.32 which time the utility must disconnect the materials or equipment.

Sec. 2. 2