

CHAPTER 5207

DEPARTMENT OF LABOR AND INDUSTRY

STANDARDS FOR CONSTRUCTION

OCCUPATIONAL SAFETY AND HEALTH STANDARDS FOR CONSTRUCTION; GENERAL		
5207.0010	ANCHOR BOLTS.	5207.0500 ENCLOSURES AT CONSTRUCTION OR ENGINEERING PROJECTS.
5207.0020	BAR, FLOOR, AND ROOF JOISTS.	5207.0510 WELLS, PITS, SHAFTS, AND OTHER SIMILAR SPACES.
5207.0030	DEMOLITION OPERATIONS.	5207.0520 WARNING SIGNS AT CONSTRUCTION OR ENGINEERING PROJECTS.
5207.0035	DEMOLITION, RESTORATION, REMODELING ASBESTOS SURVEY.	5207.0530 SIDEWALK SHEDS.
5207.0040	SPRAY PAINTING OF BUILDING INTERIORS.	5207.0540 LIGHTS AT SIDEWALK SHEDS.
5207.0050	WIRE ROPE CLIPS.	5207.0600 MACHINE GUARDING
5207.0060	FLAMMABLE LIQUID TANK SUPPORTS.	5207.0610 LOCKOUT DEVICES.
PERSONAL PROTECTIVE EQUIPMENT		5207.0620 MOTOR START BUTTON.
5207.0100	HIGH VISIBILITY PERSONAL PROTECTIVE EQUIPMENT.	5207.0630 MACHINE CONTROLS AND EQUIPMENT.
WALKING, WORKING SURFACES		5207.0640 FOOT ACTUATED MACHINES.
5207.0200	SHIPS LADDERS	5207.0700 MAINTENANCE AND REPAIR OF EQUIPMENT.
5207.0210	SHIPS LADDERS, SPECIAL REQUIREMENTS.	5207.0710 COMPRESSED GAS CONTAINERS.
5207.0250	WALKING, WORKING SURFACES	5207.0720 PRESSURE HOSES.
5207.0260	SUSPENSION SCAFFOLDS.	5207.0730 ALTERATION OF TOOLS AND EQUIPMENT.
5207.0300	CONFINED SPACES	5207.0740 LUBRICATION OF MOVING MACHINERY.
5207.0310	CARBON MONOXIDE MONITORING.	5207.0750 SCISSOR POINT PROTECTION.
ENVIRONMENTAL CONTROLS		5207.0760 SANITATION
5207.0320	GAS FIRED MACHINES AND APPLIANCES.	5207.0800 PRIVIES AT CONSTRUCTION AND ENGINEERING PROJECTS.
CRANES, HOISTS, AND DERRICKS		5207.0810 JOBSITE SHELTER
5207.0400	CRANES, HOISTS, AND DERRICKS.	5207.0900 VEHICLES
5207.0410	PERSONNEL PLATFORMS SUSPENDED FROM CRANES AND DERRICKS.	5207.0910 POWERED INDUSTRIAL TRUCK OPERATIONS.
		5207.0910 SERVICING MULTIPiece AND SINGLE PIECE RIM WHEELS.

OCCUPATIONAL SAFETY AND HEALTH STANDARDS FOR CONSTRUCTION; GENERAL

5207.0010 ANCHOR BOLTS.

During the erection phase of any structure, if the size, weight, or balance of any structural member is such that temporary anchoring with two bolts does not provide adequate support to secure it, additional support shall be provided.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0020 BAR, FLOOR, AND ROOF JOISTS.

Where bar, floor, or roof joists are set in place overhead, they shall be field bolted or welded.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0030 DEMOLITION OPERATIONS.

The cutting or removal of reinforcing steel or cables that are suspending debris, or the removal of columns or studs that support debris, shall not take place in close proximity to any area where employees are working unless the area has been isolated by protection to separate the work area from falling or sliding debris.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0035 DEMOLITION, RESTORATION, REMODELING ASBESTOS SURVEY.

Before permitting employees to start any demolition, restoration, or remodeling project where an employer has, or should have, reason to believe there are asbestos containing materials, a survey by a qualified person shall be made to determine if there are asbestos contain-

ing materials present in the structure. The project controlling employer shall have written evidence that an evaluation has been performed. If asbestos containing material is to be disturbed, removed, replaced, or repaired, the provisions of Code of Federal Regulations, title 29, section 1926.58, apply.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0040 SPRAY PAINTING OF BUILDING INTERIORS.

Subpart 1. **Nonflammable paints.** Where spray painters are applying nonflammable paint on walls, ceilings, or fixtures, at times when employees other than painters are employed in or near such areas, safeguarding measures shall be taken to protect the lives and health of spray painters and others as per code:

A. Respiratory mouth and nose masks and/or fresh air hoods shall be provided for spray painters by employers at no cost to spray painters.

B. Personal respiratory equipment shall meet the requirements of ANSI Z88.2-1969, Practices for Respiratory Protection.

C. Areas being spray painted shall be sealed off from other areas of the building by means of curtains. Employees other than painters shall not be required to work in enclosed areas.

D. Curtains shall have no openings except entry ways, which shall be kept closed during painting.

E. Cross ventilation shall be provided to remove spray paint vapors from the enclosures to the outside air by means of either mechanical exhaust or window ventilation.

F. Provisions shall be made to prevent exhaust vapors from reentering any part of the building.

Subp. 2. **Flammable paints.** In addition to meeting the requirements of subpart 1, where flammable paints are being applied, the following requirements also apply:

A. All motors, lights, switches, and electrical appliances shall be deenergized. Exception: portable vapor proof lights may be used when located 20 feet or more from the painting area.

B. The Air Quality Division of the Minnesota Pollution Control Agency should be consulted for any air pollution control measures required.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0050 WIRE ROPE CLIPS.

Subpart 1. **Location of U-bolts.** Wire rope clips attached with U-bolts shall have the U-bolts on the dead or short end of the rope.

Subp. 2. **Clip construction.** Clips shall be made of drop forged steel. All nuts on the clip bolts of a newly installed rope shall be retightened after the first hour of service.

Subp. 3. **Clip spacing.** Spacing and number of clips shall be in accordance with the table below:

Rope Diameter (inches)	Number of Clips Drop Forged	Minimum Spacing (inches)
1/8	2	3/4
3/16	2	1 -1/8
1/4	2	1 -1/2
5/16	2	1 -7/8
3/8	2	2 -1/4
7/16	2	2 -5/8
1/2	3	3
5/8	3	3 -3/4
3/4	4	4 -1/2
7/8	4	5 -1/4
1	5	6

1 - 1/8	6	6 - 1/4
1 - 1/4	6	7 - 1/2
1 - 3/8	7	8 - 1/4
1 - 1/2	7	9

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0060 FLAMMABLE LIQUID TANK SUPPORTS.

Tank supports shall be installed on firm foundations. Tank supports must be of concrete, masonry, or protected steel. Single wood timber supports (not cribbing) may be used for outside aboveground tanks if the fall potential of the tank is not more than 12 inches at the lowest point of the tank.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

PERSONAL PROTECTIVE EQUIPMENT

5207.0100 HIGH VISIBILITY PERSONAL PROTECTIVE EQUIPMENT.

Employees exposed to vehicular traffic when the work area is on the driving lanes or on the shoulders or berms, or on the median adjacent to streets, highways, or roadways shall be provided with and required to wear warning vests or other high visibility garments. For work during the hours of darkness, this protective equipment must be made of or marked with reflectorized material.

Where permanent or semipermanent barricades are installed to protect employees from vehicular traffic, high visibility vests or other high visibility equipment is not required.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

WALKING, WORKING SURFACES

5207.0200 SHIPS LADDERS.

Subpart 1. Requirement. Employers shall replace fixed and portable ladders with ships ladders whenever possible.

The angle of rise of ships ladders shall be between 50 and 60 degrees measured from the horizontal.

Subp. 2. Soffits. Where ladders are located one above the other, soffits shall be enclosed except where solid treads and risers are provided.

Subp. 3. Treads. Treads shall be uniformly spaced eight to 12 inches vertically. Tread surfaces other than steel grating shall be provided with skid resistance. Treads shall be flat steps that are a minimum of six inches wide and at least 24 inches long.

Subp. 4. Handrails. Handrails shall be provided on both sides of ladders and shall be placed to run parallel with stringers and be positioned 12 to 14 inches measured vertically, from the stringers. Handrail diameters shall be 1-1/4 to 1-5/8 inches outside diameter. When ships ladders serve door entrances, handrails shall continue to the door.

Subp. 5. Stringers. Ladder stringers shall be at least six inches in depth and permanently attached at terminations.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0210 SHIPS LADDERS, SPECIAL REQUIREMENTS.

Ships ladders shall be provided in all buildings where mechanical equipment is located on the roof in order to make all equipment accessible to maintenance and inspection personnel. Ships ladders shall be placed at an angle between 50 and 60 degrees measured from the horizontal. The opening in ceilings and building roofs shall have a minimum area of nine

square feet and a minimum width of two feet. No ships ladders shall be located in or pass through elevator shafts, elevator penthouses, or elevator machine rooms.

Inside a penthouse, handrails shall continue through ceiling and roof openings to a distance of 36 inches. A guardrail and intermediate rail shall be provided on all open sides with a substantial chain guard on the entrance.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0250 WALKING, WORKING SURFACES.

Subpart 1. **Labeling floor or wall opening covers.** In those instances where floor or wall opening covers are used, they shall be labeled, "Floor Opening — Do Not Remove," or "Wall Opening — Do Not Remove" as applicable with lettering at least two inches in height.

Subp. 2. **Displacement.** Floor or wall opening covers shall be secured against accidental displacement.

Subp. 3. **Tripping and impaling hazards.** Where employees are exposed to tripping or impaling hazards caused by projecting conduit ends, reinforcing rods, pipe ends, or similar objects, these hazards shall be barricaded, guarded, or otherwise covered.

Subp. 4. **Construction stairways.** In addition to the requirements of Code of Federal Regulations, title 29, section 1926.501, semifinished permanent stairways or temporary stairways to a second floor are to be in place before supports or structure to the sixth floor are raised. Similarly, the supports or structure on multifloored buildings shall never be more than five floors ahead of stairways.

A. On steel frame buildings, stairways shall extend to the uppermost floor that has been planked or decked. Ladders for access purposes may be used only above that point.

B. A second means of egress remote from the prime means of egress shall be provided, for emergency use, when any multifloored structure reaches the 30-foot level or the fourth floor.

C. Ladders which meet the requirements of Code of Federal Regulations, title 29, section 1926.450 may be used as a second means of egress.

Subp. 5. **Roofs.** Employees on flat roofs, other than those actually engaged in roofing operations (roofers), shall be protected from potential fall hazards as required by Code of Federal Regulations, title 29, section 1926.500(d)(1), or equivalent protection such as warning lines or tying off to a substantial building structure using an approved safety belt and lanyard.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0260 SUSPENSION SCAFFOLDS.

Subpart 1. **Multistage suspension scaffolds.** Multistage suspension scaffolds shall meet the requirements of Code of Federal Regulations, title 29, section 1926.451(i) with the exception of section 1926.451(i)(8).

In addition, the following requirements shall be met:

A. All multistage suspension scaffolds shall be equipped with at least one additional emergency support cable and automatic locking device at each end of the platform capable of supporting the work platform in the event one or both of the main suspension cables should fail.

B. The two additional emergency support cables required in item A, shall provide the required strength for a safety factor of six times the platform's intended load, including support for scaffold platforms, materials, tools, and employees working on the scaffold.

C. Employees shall tie off with a lanyard to the scaffold system in lieu of a lifeline to the building. The section of scaffold system or cable used by employees for attachment of lanyard, when tying off to the scaffold in lieu of a lifeline as required above, shall be capable of supporting at least six times the intended load.

Subp. 2. **Suspension scaffolds.** The scaffold suspension lines shall be secured to the scaffold and to the roof irons, hooks, or outriggers by bolt type devices or cable eyes and cable clamps. Hooks or safety hooks are not permitted as a means of rigging.

Subp. 3. Outrigger beams or thrustout. When a suspension scaffold is supported by outrigger beams or thrustouts, each outrigger beam or thrustout must meet the following requirements:

A. Each outrigger beam or thrustout shall be of a size and design to support four times the intended load.

B. The inner end of the outrigger beam must be secured from overturning or tilting laterally.

C. Tiebacks that meet the requirements of Code of Federal Regulations, title 29, section 1926.451(i)(4), shall be securely fastened to the outrigger beam.

D. Counterweights, when used, shall be sufficient to balance four times the intended load, shall be securely fastened to the outrigger beam, marked to indicate their weight, and of a rigid nonflowable material.

Subp. 4. Lifelines on single point suspension scaffolds. A lifeline that meets the requirements of Code of Federal Regulations, title 29, section 1926.104(b), shall be installed for single point suspension scaffolds. Employees working on the scaffold shall be provided with a safety belt and lanyard that meet the requirements of Code of Federal Regulations, title 29, section 1926.104, and shall be required to tie off to the lifeline.

Subp. 5. Broken wire safeties. When two point scaffolds are equipped with broken wire safeties, the employees may tie off to a substantial member of the scaffold itself. A "substantial member" is a member capable of withstanding the anticipated load. Guardrails are not considered substantial members. The maximum potential fall before the lanyard becomes taut shall be six feet.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0300 CONFINED SPACES.

Subpart 1. Scope. This subpart prescribes minimum safeguards for preventing employee exposure to dangerous air contamination or oxygen deficiency within such spaces as silos, tanks, vats, vessels, boilers, compartments, ducts, sewers, pipelines, vaults, bins, tubs, pits, and other similar spaces. This subpart does not apply to underwater operations conducted in diving bells or other underwater devices or to supervised hyperbaric facilities.

Subp. 2. General requirements. Work in confined spaces on construction sites shall meet the requirements of parts 5205.1000 to 5205.1040.

Statutory Authority: *MS s 182.655*

History: *12 SR 1754*

5207.0310 CARBON MONOXIDE MONITORING.

The employer shall monitor environmental exposure of employees to carbon monoxide whenever internal combustion engines discharge engine exhaust gases indoors or unvented space heaters are operated indoors to ensure that carbon monoxide levels do not exceed those given in Code of Federal Regulations, title 29, section 1910.1000, Table Z-1. The air monitoring shall be done during initial operation and at least quarterly thereafter and during a period representing highest usage in areas where carbon monoxide exposure is most likely.

Statutory Authority: *MS s 182.655*

History: *12 SR 1754*

ENVIRONMENTAL CONTROLS

5207.0320 GAS FIRED MACHINES AND APPLIANCES.

The flame of the gas pilot, burner, or burners in gas fired units shall be protected by a quick acting flame sensitive safeguard that will automatically shut off the fuel supply in case of pilot or burner failure.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

CRANES, HOISTS, AND DERRICKS**5207.0400 CRANES, HOISTS, AND DERRICKS.**

Subpart 1. **Scope.** This part applies to any crane, hoist, or derrick having a maximum rated capacity of one ton or less; to railway and automobile wrecking cranes; skip hoists; hoistlike units used for horizontal pulling only; mine hoists; conveyors and shovels; drag line excavators; backhoes; and any equipment such as mobile scaffolds, towers, and platforms.

Subp. 2. **General requirements.** Cranes, hoists, or derricks within the scope of this part shall meet the requirements of parts 5205.1200 to 5205.1210.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0410 PERSONNEL PLATFORMS SUSPENDED FROM CRANES AND DERRICKS.

The design, construction, testing, use, and maintenance of personnel platforms and the hoisting of personnel platforms on the load lines of cranes or derricks shall meet the requirements of Code of Federal Regulations, title 29, 1926.550, paragraph (g).

Statutory Authority: *MS s 182.655*

History: *12 SR 634; 17 SR 1273*

5207.0500 ENCLOSURES AT CONSTRUCTION OR ENGINEERING PROJECTS.

The ground actually occupied by the building construction operations or engineering project shall be shut off by an enclosure from places accessible to the public. The enclosure shall be such as to avoid any risk that might arise from the fall of any objects whatsoever. Places on the building site that are accessible to the workers shall be protected in a similar manner.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0510 WELLS, PITS, SHAFTS, AND OTHER SIMILAR SPACES.

All wells, pits, shafts, and other similar spaces shall be barricaded or covered. Upon completion of exploration and similar operations, temporary wells, pits, shafts, and other similar spaces shall be backfilled.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0520 WARNING SIGNS AT CONSTRUCTION OR ENGINEERING PROJECTS.

Warning signs, or warning signs and red lights shall be conspicuously placed and maintained at all dangerous places on the job.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0530 SIDEWALK SHEDS.

Whenever a building shall be erected or increased over two stories in height, or whenever a building of more than 25 feet in height is to be demolished upon any street of a municipality on which municipal regulations will not allow sidewalks to be blockaded, the owner, builder, or contractor constructing, repairing, or demolishing the building shall erect and maintain, during the period of construction and repair, a shed which shall extend over not less than one-half the width of the sidewalk and shall have a minimum width of three feet. The side wall toward the building shall be sealed with boards. The roof over the shed shall be constructed to support the approximate load carried, but in no case shall the planks on the roof be less than two inches thick or at least 3/4-inch plywood. The street side of the sidewalk shed shall have a hand and an intermediate rail.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0540 LIGHTS AT SIDEWALK SHEDS.

Every sidewalk shed shall be kept in good repair, free from unnecessary obstruction, and properly lighted at night. The ends of the sidewalk shed walk shall be marked with red lights on the street side.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

MACHINE GUARDING**5207.0600 LOCKOUT DEVICES.**

Subpart 1. **Electrical power disconnect.** Any main electrical power disconnect means which controls a source of power or material flow shall be locked out with a lockout device whenever employees are maintaining, cleaning, adjusting, or servicing machinery or equipment, if the disconnect is not in clear sight of the employee. A "Do-Not Start" tag as described in Code of Federal Regulations, title 29, section 1910.145(f)(3), shall be affixed to any and all operating controls.

Subp. 2. **Pneumatic and hydraulic lines.** The pressure shall be eliminated from any pneumatic and hydraulic lines that activate a mechanism or machine, and the valve holding back the activating substance shall be locked out before an employee works on that mechanism or machine.

Subp. 3. **Spring tension mechanisms.** Mechanisms under spring tension or compression shall be blocked, clamped, secured in position, or the compression or tension totally relieved before being worked on by an employee.

Subp. 4. **Suspended mechanisms.** Suspended mechanisms or parts that normally cycle through a lower position shall be lowered to the lowest position, be clamped, blocked, or otherwise secured in position before being worked on by an employee.

Subp. 5. **Individual lockouts.** Where more than one employee is engaged in working on machinery or equipment, each employee shall affix the employee's individual lockout device or lock to the disconnect switch or power supply.

Subp. 6. **Exemption.** Utility companies, when working on lines and equipment, will be exempt from this standard but must comply with the requirements of Code of Federal Regulations, title 29, section 1926.950(d).

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0610 MOTOR START BUTTON.

The motor start button on machines with exposed points of operation, pinch points, or nip points shall be physically protected against unintended operation.

Statutory Authority: *MS s 182.655*

History: *12 SR 1754*

5207.0620 MACHINE CONTROLS AND EQUIPMENT.

On machines with points of operation, pinch points, or nip points, each machine shall be equipped so it is possible for the operator to cut off the power to each machine without leaving the position at the point of operation.

Statutory Authority: *MS s 182.655*

History: *12 SR 1754*

5207.0630 FOOT ACTUATED MACHINES.

The treadle or pedal of foot actuated machines, tools, or equipment shall be physically protected to prevent unintended operation.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

MAINTENANCE AND REPAIR OF EQUIPMENT**5207.0700 COMPRESSED GAS CONTAINERS.**

Valves on compressed gas containers shall be protected from damage while in use or storage.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0710 PRESSURE HOSES.

All hand held pressure hoses and nozzles that could cause injury when the hose or nozzle is not being held, including air, water, hot water and steam, and all high temperature hoses or nozzles including hot water and steam, shall have a constant pressure control.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0720 ALTERATION OF TOOLS AND EQUIPMENT.

All tools and equipment, whether powered or manually operated, shall be used only for their intended purpose. Tools and equipment shall not be altered, modified, or used for other than their intended purpose without the manufacturer's written approval, or unless under the direction of a competent person in accordance with accepted engineering requirements to prevent creating an additional hazard.

Statutory Authority: *MS s 182.655*

History: *12 SR 1754*

5207.0730 LUBRICATION OF MOVING MACHINERY.

Machinery or equipment shall be shut down during manual lubrication unless access to lubrication fittings is safeguarded or is located far enough away from moving parts that employees cannot contact them.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0740 SCISSOR POINT PROTECTION.

Scissor points on all rubber tired skid steer equipment including front end loaders shall be guarded to protect the operator.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

SANITATION**5207.0800 PRIVIES AT CONSTRUCTION AND ENGINEERING PROJECTS.**

Privies shall be provided on all construction and engineering projects as provided for in the sanitation laws of Minnesota. Privies shall be placed inside of heated buildings wherever possible to do so. Where privies are not placed inside of heated buildings, provisions shall be made for heating privies to a minimum of heat that can be emitted from the installation of a 1,300 watt heater or other type equivalent heater.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0810 JOBSITE SHELTER.

Subpart 1. Definitions. "Suitable place" means an enclosed shed, designated area within a new or existing structure, or van, panel truck, or mobile home. A "worker day" is equivalent to one person working an eight-hour shift.

Subp. 2. Scope. The provisions of this standard apply to those construction projects which have exceeded 30 worker days.

Subp. 3. Place to change and eat. From November 1 to March 15 of each winter season, all construction jobs shall be provided with a suitable place for employees to change their clothes and eat their lunch.

Subp. 4. Size. The size of jobsite shelters shall be based on the maximum number of employees using the room at one time. The minimum space requirements, in square feet per person, shall be determined by the values as shown below:

- A. 25 or fewer employees, 13 square feet;
- B. 26 to 74 employees, 12 square feet;
- C. 75 to 149 employees, 11 square feet; and
- D. 150 employees and over, ten square feet.

Subp. 5. Temperature. Jobsite shelters shall be heated to a temperature of at least 50 degrees Fahrenheit during all periods when the shelter is occupied.

Subp. 6. Contaminated clothing storage. If toxic or harmful substances are handled so that work clothes become contaminated, facilities shall be provided so that street clothes and work clothes will not be stored in contact with each other.

Subp. 7. Lighting. Jobsite shelters shall be lighted with not less than ten footcandles of light.

Subp. 8. Crew mobility. The requirements of this standard can be met by furnishing transportation to a reasonably convenient location which meets the other requirements of this standard.

Statutory Authority: *MS s 182.655*

History: *12 SR 634; 17 SR 1279*

VEHICLES

5207.0900 POWERED INDUSTRIAL TRUCK OPERATIONS.

Industrial trucks designed and constructed solely for use on solid hard level surfaces shall be restricted to such operations.

All solid hard level surfaces must be free of cracks, irregularities, or holes that could upset the balance of the industrial truck.

When a fork truck operator is positioning a load in an area that is not fully visible to the fork truck operator, the operator shall be assisted by a designated person who shall direct the safe placing of the load by using predetermined signals.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*

5207.0910 SERVICING MULTIPIECE AND SINGLE PIECE RIM WHEELS.

Subpart 1. Scope. This subpart applies to the servicing of multipiece and single piece rim wheels used on large vehicles such as trucks, tractors, off road machines, and similar vehicles used on construction sites. It does not apply to the servicing of rim wheels used on automobiles or pickup trucks and vans using automobile tires or truck tires designated "LT."

Subp. 2. General requirements. Servicing of multipiece and single piece rim wheels on large vehicles on construction sites shall meet the requirements of Code of Federal Regulations, title 29, section 1910.177.

Statutory Authority: *MS s 182.655*

History: *12 SR 634*