

CHAPTER 4720
DEPARTMENT OF HEALTH
PUBLIC WATER SUPPLIES

| | | | |
|-----------|--|-----------|---|
| 4720.0010 | WATER SUPPLY AND SEWERAGE SYSTEMS. | 4720.1900 | ANALYTICAL METHODS. |
| 4720.0015 | FEES FOR REVIEW OF PLANS. | 4720.2000 | ALTERNATIVE ANALYTICAL TECHNIQUES. |
| 4720.0020 | UNSAFE WATER CONNECTIONS. | 4720.2100 | APPROVED LABORATORIES. |
| 4720.0030 | FLOURIDATION. | 4720.2200 | MONITORING CONSECUTIVE SYSTEMS. |
| 4720.0040 | MUNICIPALITY APPROVAL OF WATER SUPPLY CONTRACTS. | 4720.2300 | ADDITIONAL MONITORING REQUIREMENTS. |
| 4720.0100 | DEFINITIONS. | 4720.2400 | SPECIAL MONITORING FOR SODIUM. |
| 4720.0200 | JUSTIFICATION. | 4720.2500 | SPECIAL MONITORING FOR CORROSIVITY CHARACTERISTICS. |
| 4720.0300 | SCOPE AND COVERAGE. | 4720.2600 | VARIANCES. |
| 4720.0400 | MAXIMUM CONTAMINANT LEVELS. | 4720.2700 | APPLICATION PROCEDURE FOR VARIANCE. |
| 4720.0500 | MAXIMUM LEVEL OF MICROBIOLOGICAL CONTAMINANTS. | 4720.2800 | DISPOSITION OF A REQUEST FOR A VARIANCE. |
| 4720.0600 | MAXIMUM CONTAMINANT LEVELS OF TURBIDITY. | 4720.2900 | TERMINATION OF A VARIANCE. |
| 4720.0700 | MAXIMUM LEVEL OF INORGANICS. | 4720.3000 | COMPLIANCE WITH VARIANCE. |
| 4720.0800 | MAXIMUM CONTAMINANT LEVEL OF ORGANIC CHEMICALS. | 4720.3100 | EXEMPTIONS. |
| 4720.0900 | MAXIMUM LEVEL OF RADIOLOGICAL CONTAMINANTS. | 4720.3200 | APPLICATION PROCEDURE FOR EXEMPTION. |
| 4720.1000 | MONITORING AND ANALYTICAL REQUIREMENTS. | 4720.3300 | DISPOSITION OF A REQUEST FOR AN EXEMPTION. |
| 4720.1100 | REFERENCES FOR ANALYTICAL PROCEDURES. | 4720.3400 | TERMINATION OF AN EXEMPTION. |
| 4720.1200 | MICROBIOLOGICAL CONTAMINANT SAMPLING AND ANALYTICAL REQUIREMENTS. | 4720.3500 | COMPLIANCE WITH EXEMPTION. RECORD MAINTENANCE; REPORTING; PUBLIC NOTIFICATION |
| 4720.1300 | TURBIDITY SAMPLING AND ANALYTICAL REQUIREMENTS. | 4720.3600 | RECORD MAINTENANCE. |
| 4720.1400 | INORGANIC CHEMICAL CONTAMINANT SAMPLING AND ANALYTICAL REQUIREMENTS. | 4720.3700 | REPORTING REQUIREMENTS. |
| 4720.1500 | ORGANIC CHEMICAL CONTAMINANT SAMPLING AND ANALYTICAL REQUIREMENTS. | 4720.3800 | RIGHT OF INSPECTION. |
| 4720.1600 | TRIHALOMETHANE SAMPLING. | 4720.3900 | PUBLIC NOTIFICATION. |
| 4720.1700 | MONITORING REQUIREMENTS FOR GROSS ALPHA PARTICLE ACTIVITY, RADIUM-226, AND RADIUM-228. | 4720.3910 | TYPHOID FEVER. WATER HAULERS |
| 4720.1800 | MONITORING REQUIREMENTS FOR MAN-MADE RADIOACTIVITY. | 4720.4000 | PURPOSE. |
| | | 4720.4100 | DEFINITIONS. |
| | | 4720.4200 | WATER HAULER. |
| | | 4720.4300 | TANK REQUIREMENTS. |
| | | 4720.4400 | CLEANING AND DISINFECTION. |
| | | 4720.4500 | TESTING. |
| | | 4720.4600 | RECORDS. |
| | | 4720.5000 | LABORATORY ANALYSIS FEES. |

4720.0010 WATER SUPPLY AND SEWERAGE SYSTEMS.

No system of water supply or system for the disposal of sewage, industrial waste, garbage, or refuse, in case any such system is for public use or for the use of any considerable number of persons, or in case any such system affects or tends to affect the public health in any manner, shall be installed by any public agency or by any person or corporation, nor shall any such existing system be materially altered or extended, until complete plans and specifications for the installation, alteration, or extension, together with such information as the commissioner of health may require, have been submitted in duplicate and approved by the commissioner of health insofar as any features thereof affect or tend to affect the public health, and no construction shall take place except in accordance with the approved plans.

Statutory Authority: *MS s 144.08; 144.12 subd 1; 144.381 to 144.388*

History: *L 1977 c 305 s 39*

4720.0015 FEES FOR REVIEW OF PLANS.

All plans for water supply system construction, alteration, or extension submitted for review and approval to the Department of Health as required in

4720.0015 PUBLIC WATER SUPPLIES

4198

part 4720.0010 shall be accompanied by the appropriate fees, as prescribed below:

- A. Watermains, \$150;
- B. Wells, \$250;
- C. Pumphouses, \$150;
- D. Chemical feed, \$150;
- E. Treatment plants (new), \$1,000;
- F. Treatment plants (renovation), \$250;
- G. Storage (installation), \$300;
- H. Storage (coating), \$100; and
- I. Booster stations, \$150.

The appropriate fees shall be paid by check made payable to "Minnesota Department of Health."

Statutory Authority: *MS s 144.383*

History: *10 SR 1687*

4720.0020 UNSAFE WATER CONNECTIONS.

There shall be no physical connection between water supply systems that are safe for domestic use and those that are unsafe for domestic use.

There shall be no provision for such a connection or arrangement by which unsafe water may be discharged or drawn into a safe water supply system.

Statutory Authority: *MS s 144.08; 144.12 subd 1; 144.381 to 144.388*

4720.0030 FLOURIDATION.

Subpart 1. Application. This part shall be applicable to all municipal water supplies, as required by Minnesota Statutes, section 144.145.

Subp. 2. Fluoride content. The fluoride content of the water shall be controlled to maintain an average concentration of 1.2 milligrams per liter; the concentration shall be neither less than 0.9 milligrams per liter nor more than 1.5 milligrams per liter.

Subp. 3. Chemical feeder. The chemical feeder apparatus for introducing fluoride to the water supply shall conform to the standards of the commissioner of health.

Subp. 4. Testing. Equipment for the adequate and reliable testing of the fluoride content shall be furnished for each installation. The method of testing the fluoride content of the water shall be approved by the commissioner of health. Approval shall require either a photometric colorimetric procedure, preceded when necessary by distillation or other treatment to remove interfering materials, or a fluoride-specific electrode and an associated potential measuring device. Continuous monitoring systems shall be approved when they can be installed to monitor a representative portion of the entire supply.

Subp. 5. Samples collected daily. Samples shall be collected daily at a point(s) in the distribution system representative of the entire supply. Sampling point(s) shall be located downstream sufficiently distant from the point(s) at which fluoride is fed into the water supply to ensure that the distance traversed and the time elapsed since the introduction of the fluoride concentrate is adequate to allow its complete mixing with the water. At least once each three months, at a time designated by the commissioner of health, a duplicate of the usual daily sample(s) shall be collected in containers furnished by the commissioner of health and sent to the Department of Health for comparative analysis.

Subp. 6. Records of fluoridation. Daily records of water fluoridation plant operations shall be maintained by the owners, officials, or their representatives. These records shall show the amount of water pumped, amount of fluoride

chemical fed, fluoride test results, and any other pertinent information required by the commissioner of health. A report of the operation of each water fluoridation plant shall be submitted monthly to the commissioner of health on forms furnished by them.

Statutory Authority: *MS s 144.12 subd 1; 144.381 to 144.388; 144.145*

History: *L 1977 c 305 s 39*

4720.0040 MUNICIPALITY APPROVAL OF WATER SUPPLY CONTRACTS.

No governing body of any municipality shall enter into any contract or agreement or renewal thereof for the furnishing and distribution, either or both, of water to be used for domestic purposes within the municipality until the approval of the commissioner of health, insofar as the sanitary features of the water supply system are concerned, has been obtained.

Statutory Authority: *MS s 144.12 subd 1*

History: *L 1977 c 305 s 39*

4720.0100 DEFINITIONS.

Subpart 1. Scope. The following definitions apply to parts 4720.0100 to 4720.3900, unless the context indicates otherwise.

Subp. 2. Commissioner. "Commissioner" means the commissioner of health, or his or her authorized representative.

Subp. 3. Disinfectant. "Disinfectant" means any oxidant, including but not limited to chlorine, chlorine dioxide, chloramines, and ozone added to water in any part of the treatment or distribution process, that is intended to kill or inactivate pathogenic microorganisms.

Subp. 4. Dose equivalent. "Dose equivalent" means the product of the absorbed dose from ionizing radiation and such factors as account for differences in biological effectiveness due to the type of radiation and its distribution in the body as specified by the International Commission on Radiological Units and Measurements (ICRU).

Subp. 5. Exemption. "Exemption" means a waiver which may be granted by the commissioner to a supply which is in operation on June 24, 1977:

A. when a maximum contaminant level or required treatment cannot be complied with because of economic or other compelling factors; and

B. if granting the waiver will not result in an unreasonable risk to health.

Such an exemption must be conditioned upon a schedule for compliance with these rules by the dates specified in part 4720.3500.

Subp. 6. Federal act. "Federal act" means the Safe Drinking Water Act of 1974, Public Law Number 93-523, title 42, United States Code, section 300, clause f, and amendments thereto.

Subp. 7. Federal regulations. "Federal regulations" means regulations dealing with public water supplies and drinking water quality, promulgated by the Administrator of the United States Environmental Protection Agency pursuant to the federal act.

Subp. 8. Gross alpha particle activity. "Gross alpha particle activity" means the total radioactivity due to alpha particle emission as inferred from measurements on a dry sample.

Subp. 9. Gross beta particle activity. "Gross beta particle activity" means the total radioactivity due to beta particle emission as inferred from measurements on a dry sample.

Subp. 10. Halogen. "Halogen" means one of the chemical elements chlorine, bromine, or iodine.

Subp. 11. **Man-made beta particle and photon emitters.** "Man-made beta particle and photon emitters" means all radionuclides emitting beta particles or photons listed in "Maximum Permissible Body Burdens and Maximum Permissible Concentration of Radionuclides in Air or Water for Occupational Exposure," NBS Handbook 69, except the daughter products of thorium-232, uranium-235, and uranium-238.

Subp. 12. **Maximum contaminant level.** "Maximum contaminant level" means the maximum permissible level of a contaminant (any physical, chemical, biological, or radiological substance or matter) in water which is delivered to the free flowing outlet of the ultimate user of a public water supply; except in the case of turbidity where the maximum permissible level is measured at the point of entry to the distribution system. Contaminants added to the water under circumstances controlled by the user, except for those resulting from corrosion of piping and plumbing caused by water quality, are excluded from this definition.

Subp. 13. **Maximum total trihalomethane potential.** "Maximum total trihalomethane potential" means the maximum concentration of total trihalomethanes produced in a given water containing a disinfectant residual after seven days at a temperature of 25 degrees Celsius or above.

Subp. 14. **Person.** "Person" means an individual, partnership, copartnership, cooperative, public or private association or corporation, public subdivision, agency of the state or federal government or any other legal entity or its legal representative, agent, or assigns.

Subp. 15. **Picocurie.** "Picocurie (pCi)" means that quantity of radioactive material producing 2.22 nuclear transformations per minute.

Subp. 16. **Public water supply.** "Public water supply" or "supply" means a system providing piped water for human consumption, and either containing a minimum of 15 service connections or 15 living units, or serving at least 25 persons daily for 60 days of the year. Such term includes:

A. Any collection, treatment, storage, and distribution facilities under control of the operator of the supply and used primarily in connection with the supply; and

B. Any collection or pretreatment storage facilities used primarily in connection with the supply but not under control of the operator. A public water supply is either a community or a noncommunity water supply.

(1) "Community water supply" means a public water supply or system which serves at least 15 service connections or living units used by year-round residents, or regularly serves at least 25 year-round residents.

(2) "Noncommunity water supply" means any public water supply that is not a community water supply. The following are given as examples of noncommunity water supplies and are in no way meant to be an exhaustive list: seasonal facilities such as children's camps, recreational camping areas, resorts, or year-round facilities which serve at least 25 persons who are not residents thereof, such as churches, entertainment facilities, factories, gasoline service stations, marinas, migrant labor camps, office buildings, parks, restaurants, schools.

Subp. 17. **Rem.** "Rem" means the unit of dose equivalent from ionizing radiation to the total body or any internal organ or organ system. A "millirem (mrem)" is 1/1000 of a rem.

Subp. 18. **Sanitary survey.** "Sanitary survey" means an on-site review of the water source, facilities, equipment, operation, and maintenance of a public water supply for the purpose of evaluating the adequacy of the source, facilities, equipment, operation, and maintenance for producing and distributing safe drinking water.

Subp. 19. **Standard sample.** "Standard sample" means the aliquot of finished drinking water that is examined for the presence of coliform bacteria.

Subp. 20. **Supplier.** "Supplier" means any person who owns, manages, or

MINNESOTA RULES 1987

4201

PUBLIC WATER SUPPLIES 4720.0300

operates a public water supply, whether or not he is an operator certified pursuant to Minnesota Statutes, sections 115.71 to 115.82.

Subp. 21. **Total trihalomethanes.** "Total trihalomethanes" means the sum of the concentration in milligrams per liter of the trihalomethane compounds of trichloromethane (chloroform), dibromochloromethane, bromodichloromethane, and tribromomethane (bromoform), rounded to two significant figures.

Subp. 22. **Trihalomethane.** "Trihalomethane" means one of the family of organic compounds named as derivatives of methane, wherein three of the four hydrogen atoms in methane are each substituted by a halogen atom in the molecular structure.

Subp. 23. **Turbidity unit.** "Turbidity unit" means an amount of turbidity equivalent to that in a solution composed of .000125 percent hydrazine sulfate and .00125 percent hexamethylenetetramine in distilled and filtered (100 μ pore size membrane) water, as measured by a nephelometric turbidimeter.

Subp. 24. **Variance.** "Variance" means a waiver which may be granted by the commissioner to a supply:

A. which, due to the raw water quality reasonably available, cannot comply with a maximum contaminant level, despite application of the best known and available technology for treatment or other means; and

B. if granting the waiver will not result in an unreasonable risk to health.

Such a variance must be conditioned upon a schedule for implementation of control measures, and may specify an indefinite time period for compliance with the maximum contaminant level or required treatment.

Subp. 25. **Year round resident.** "Year round resident" means a person who resides in the area served by the public water supply for more than six months of the year.

Statutory Authority: *MS s 144.381 to 144.388*

4720.0200 JUSTIFICATION.

Parts 4720.0100 to 4720.3900 are adopted pursuant to legislative authority granted in Laws of Minnesota 1977, chapter 66, section 3, clause (e), which requires that the commissioner of health adopt for all public water supplies rules which are at least as stringent as the federal regulations dealing with public water supplies adopted by the United States Environmental Protection Agency, in order for the commissioner to be able to assume the primary responsibility for enforcing the federal act.

Statutory Authority: *MS s 144.381 to 144.388*

4720.0300 SCOPE AND COVERAGE.

Parts 4720.0100 to 4720.3900 prescribe standards for water supply siting and construction, set maximum contaminant levels for turbidity, microbiological constituents, organic and inorganic chemicals, and radioactivity, prescribe a frequency for monitoring the levels of these constituents and sodium and corrosivity, and prescribe the procedures for reporting results, notifying the public and for maintaining records.

The standards and procedures adopted in parts 4720.0100 to 4720.3900 inclusive shall apply to all public drinking water supplies, pursuant to authority granted by existing statutes and amendments thereto, notwithstanding any other water quality standards or regulations.

A water supply which meets all of the following requirements shall not be a public supply for the purpose of parts 4720.0100 to 4720.3900:

- A. consists only of distribution and storage facilities;
- B. obtains all of its water from, but is not owned or operated by a public water supply to which such regulations apply;

4720.0300 PUBLIC WATER SUPPLIES

4202

C. does not sell water to any person; and

D. is not a carrier which conveys passengers in intrastate commerce.

Statutory Authority: *MS s 144.381 to 144.388*

4720.0400 MAXIMUM CONTAMINANT LEVELS.

The levels in parts 4720.0500 to 4720.0900 shall be the enforceable maximum contaminant levels for all public water supplies in the state.

Statutory Authority: *MS s 144.381 to 144.388*

4720.0500 MAXIMUM LEVEL OF MICROBIOLOGICAL CONTAMINANTS.

Subpart 1. Maximum contaminant levels. The maximum contaminant levels for coliform bacteria, applicable to both community and noncommunity water supplies, are as follows in subparts 2 to 6.

Subp. 2. Use of membrane filter. When the membrane filter technique pursuant to part 4720.1200, subpart 1, item A is used, the number of coliform bacteria shall not exceed any of the following:

A. One per 100 milliliters as the arithmetic mean of all samples examined per compliance period pursuant to part 4720.1200, subpart 2 or 3, except that systems required to take ten or fewer samples per month may exclude one positive routine sample per month from the monthly calculation if:

(1) the commissioner determines and indicates in writing to the public water supply that no unreasonable risk to health existed, after having considered the following factors: the system provided and had maintained an active disinfectant residual in the distribution system; the potential for contamination as indicated by a sanitary survey; and the history of the water quality at the public water supply;

(2) the supplier initiates a check sample on each of two consecutive days from the same sampling point within 24 hours after notification that the routine sample is positive, and each of these check samples is negative; and

(3) the original positive routine sample is reported and recorded by the supplier pursuant to parts 4720.3600 and 4720.3700.

The supplier shall report to the commissioner its compliance with the conditions specified in this item and a summary of the corrective action taken to resolve the prior positive sample result. If a positive routine sample is not used for the monthly calculation, another routine sample must be analyzed for compliance purposes. This provision may be used only once during two consecutive compliance periods.

B. Four per 100 milliliters in more than one sample when less than 20 are examined per month; or

C. Four per 100 milliliters in more than five percent of the samples when 20 or more are examined per month.

Subp. 3. Use of fermentation tube and ten-milliliter standard. When the fermentation tube method and ten-milliliter standard portions pursuant to part 4720.1200, subpart 1, item B are used, coliform bacteria shall not be present in any of the following:

A. More than ten percent of the portions in any month pursuant to part 4720.1200, subpart 2 or 3, except that systems required to take ten or fewer samples per month may exclude one positive routine sample resulting in one or more positive tubes per month from the monthly calculation if:

(1) the commissioner determines that the supply maintains an active disinfectant residual in the distribution system, or the commissioner determines in writing to the public water system that no unreasonable risk to health existed under the circumstances;

MINNESOTA RULES 1987

4203

PUBLIC WATER SUPPLIES 4720.0500

(2) the supplier initiates a check sample on each of two consecutive days from the sampling point within 24 hours after notification that the routine sample is positive, and each of these check samples is negative; and

(3) the original positive routine sample is reported and recorded by the supplier pursuant to parts 4720.3600 and 4720.3700.

The supplier shall report to the commissioner its compliance with the conditions specified in item A and a summary of the action taken to resolve the prior positive sample result. If a positive routine sample is not used for the monthly calculation, another routine sample must be analyzed for compliance purposes. This provision may be used only once during two consecutive compliance periods.

B. Three or more portions in more than one sample when less than 20 samples are examined per month; or

C. Three or more portions in more than five percent of the samples when 20 or more samples are examined per month.

Subp. 4. Use of fermentation tube and 100 milliliter standard. When the fermentation tube method and 100 milliliter standard portions pursuant to part 4720.1200, subpart 1, item B are used, coliform bacteria shall not be present in any of the following:

A. More than 60 percent of the portions in any month pursuant to part 4720.1200, subpart 2 or 3; except that systems required to take ten or fewer samples per month may exclude one positive routine sample resulting in one or more positive tubes per month from the monthly calculation if:

(1) the commissioner determines that the supplier maintains an active disinfectant residual in the distribution system, or the commissioner determines in writing to the public water system that no unreasonable risk to health existed under the circumstances;

(2) the supplier initiates two consecutive daily check samples from the same sampling point within 24 hours after notification that the routine sample is positive, and each of these check samples is negative; and

(3) the original positive routine sample is reported and recorded by the supplier pursuant to parts 4720.3600 and 4720.3700.

The supplier shall report to the state its compliance with the conditions specified in item A and a summary of the corrective action taken to resolve the prior positive sample result. If a positive routine sample is not used for the monthly calculation, another routine sample must be analyzed for compliance purposes. This provision may be used only once during two consecutive compliance periods.

B. Five portions in more than one sample when less than five samples are examined per month; or,

C. Five portions in more than 20 percent of the samples when five or more samples are examined per month.

Subp. 5. Compliance. For community or noncommunity supplies that are required to sample at a rate of less than four per month, compliance with subpart 2, 3, or 4 shall be based upon sampling during a three-month period, except that, at the discretion of the commissioner compliance may be based upon sampling during a one-month period.

Subp. 6. Average violation caused by single sample. If an average maximum contaminant level violation is caused by a single sample maximum contaminant level violation, then the case shall be treated as one violation with respect to the public notification requirements of part 4720.3900.

Statutory Authority: *MS s 144.381 to 144.388*

4720.0600 MAXIMUM CONTAMINANT LEVELS OF TURBIDITY.

The maximum contaminant levels for turbidity are applicable to both community and noncommunity water supplies using surface water sources in whole or in part. The maximum contaminant levels for turbidity in drinking water, measured at a representative entry point(s) to the distribution system, are:

A. one turbidity unit (t.u.) rounded off to the nearest whole number, as determined by a monthly average pursuant to part 4720.1300;

B. five turbidity units based on an average for two consecutive days, pursuant to part 4720.1300; and

C. a variance or exemption may be granted according to the procedure described in parts 4720.2600 to 4720.3500, to permit the supplier to provide water which contains five or less turbidity units, if the supplier can demonstrate to the commissioner that the higher turbidity does not do any of the following: interfere with disinfection; prevent maintenance of an effective disinfectant agent throughout the distribution system; or interfere with microbiological determinations.

Statutory Authority: *MS s 144.381 to 144.388*

4720.0700 MAXIMUM LEVEL OF INORGANICS.

Subpart 1. Maximum levels in community water supplies. The following are the maximum contaminant levels in milligrams per liter, for inorganic chemicals applicable to community water supplies:

- A. arsenic, 0.05;
- B. barium, 1.0;
- C. cadmium, 0.010;
- D. chromium, 0.05;
- E. fluoride, 2.2;
- F. lead, 0.05;
- G. mercury, 0.002;
- H. nitrate (as N), 10.0;
- I. selenium, 0.01; and
- J. silver, 0.05.

Subp. 2. Compliance. Compliance with maximum contaminant levels for inorganic chemicals shall be calculated in accordance with part 4720.1400, subparts 3 to 6.

Subp. 3. Noncommunity water supplies. The maximum contaminant level for nitrate listed in subpart 1 also applies to noncommunity water supplies, except that a nitrate level not in excess of 20 milligrams per liter may be allowed in a noncommunity water supply if the supplier demonstrates to the satisfaction of the commissioner that:

- A. the water will not be available to children under six months of age;
- B. there will be continuous posting of the fact that nitrate levels exceed ten milligrams per liter and the potential health effects of exposure;
- C. local public health authorities and the commissioner will be notified annually of nitrate levels that exceed ten milligrams per liter; and
- D. no adverse health effects shall result.

Statutory Authority: *MS s 144.381 to 144.388*

4720.0800 MAXIMUM CONTAMINANT LEVEL OF ORGANIC CHEMICALS.

Subpart 1. Levels for community water supplies. The following are the maximum contaminant levels for organic chemicals. They apply only to community water supplies. Compliance with maximum contaminant levels for organic chemicals is calculated pursuant to part 4720.1500, subparts 2, 3, and 4.

MINNESOTA RULES 1987

4205

PUBLIC WATER SUPPLIES 4720.0900

A. Chlorinated hydrocarbons:

(1) Endrin (1,2,3,4,10, 10-hexachloro-6,7-epoxy-1, 4, 4a,5,6,7,8,8a-octa-hydro- 1,4-endo, endo-5,8-dimethano-naphthalene), 0.0002 milligrams per liter;

(2) Lindane (1,2,3,4,5,6-hexachloro-cyclohexane, gamma isomer), 0.004 milligrams per liter;

(3) Methoxychlor (1,1,1-Trichloro 2,2-bis [p-methoxyphenyl] ethane), 0.1 milligrams per liter;

(4) Toxaphene (C₁₀H₁₀Cl₈-Technical chlorinated camphene, 67-69 percent chlorine), 0.005 milligrams per liter.

B. Chlorophenoxy:

(1) 2,4-D, (2,4-Dichlorophenoxyacetic acid), 0.1 milligrams per liter;

(2) 2,4,5-TP Silvex (2,4,5-Trichloro- phenoxypropionic acid), 0.01 milligrams per liter.

Subp. 2. **Maximum level for trihalomethane.** The maximum contaminant level for total trihalomethane is 0.10 milligrams per liter. This maximum contaminant level applies only to public water supplies which serve a population of 10,000 or more persons, and which add a disinfectant (oxidant) to the water in any part of the drinking water treatment process. Compliance with the maximum contaminant level for total trihalomethane shall be calculated in accordance with part 4720.1600.

Statutory Authority: *MS s 144.381 to 144.388*

4720.0900 MAXIMUM LEVEL OF RADIOLOGICAL CONTAMINANTS.

Subpart 1. **Community water supplies.** Maximum contaminant levels for radiological materials shall apply only to community water supplies.

Subp. 2. **Levels for radium 226, radium 228, gross alpha particle radioactivity.** Maximum contaminant levels for radium-226, radium-228, and gross alpha particle radioactivity:

A. combined radium-226 and radium-228, 5 pCi/l; and

B. gross alpha particle activity (including radium-226 but excluding radon and uranium), 15 pCi/l.

Subp. 3. **Levels for beta particle and photon radioactivity.** Maximum contaminant levels for beta particle and photon radioactivity from man-made radionuclides:

A. The average annual concentration of beta particle and photon radioactivity from man-made radionuclides in drinking water shall not produce an annual dose equivalent to the total body or any internal organ greater than four millirem/year.

B. Except for the radionuclides listed in item C, the concentration of man-made radionuclides causing four or more millirem total body or organ dose equivalents shall be calculated on the basis of a two liter per day drinking water intake using the 168 hour data listed in "Maximum Permissible Body Burdens and Maximum Permissible Concentration of Radionuclides in Air or Water for Occupational Exposure," NBS Handbook 69 as amended August 1963, U.S. Department of Commerce. If two or more radionuclides are present, the sum of their annual dose equivalent to the total body or to any organ shall not exceed four millirem/year.

C. Table A: the following table shows average annual concentrations assumed to produce a total body or organ dose of four millirem/year.

| Radionuclide | Critical Organ | pCi/l |
|--------------|----------------|--------|
| Tritium | Total body | 20,000 |

Strontium-90

Bone marrow

8

Statutory Authority: *MS s 144.381 to 144.388***4720.1000 MONITORING AND ANALYTICAL REQUIREMENTS.**

It shall be the responsibility of the supplier of water to monitor the quality of the water in his supply, according to the sampling schedules and testing procedures prescribed in parts 4720.1000 to 4720.2500. Where a supplier has the capability for on-site testing for turbidity and/or maintains a laboratory approved to test for coliform bacteria, such supplier shall follow the relevant procedures in the appropriate parts of parts 4720.1000 to 4720.2500. If an approved on-site laboratory is not available, the supplier of water shall send his water samples to an appropriate approved testing laboratory, according to procedures prescribed by the commissioner. Such procedures shall be prescribed for each supplier, and shall include a description of the type of container to be used, the manner in which the container shall be handled and delivered to the laboratory, and the date by which a sample must be sent to the approved laboratory for testing.

Statutory Authority: *MS s 144.381 to 144.388***4720.1100 REFERENCES FOR ANALYTICAL PROCEDURES.**

Subpart 1. Scope. The following terms, which are used in parts 4720.1200 to 4720.2500, shall have the meanings given them. The department will make available to the public any analytical method referenced in this rule if the method is not available for lending from a public library.

Subp. 2. ASTM. "ASTM" means "Annual Book of ASTM Standards," Part 31 Water, 1979, American Society for Testing and Materials, 1916 Race Street, Philadelphia, Pennsylvania 19103.

Subp. 3. EPA chemical. "EPA chemical" means Methods of Chemical Analysis of Water and Wastes, United States Environmental Protection Agency, Environmental Monitoring and Support Laboratory, Cincinnati, Ohio 45268 (EPA-600/4-79-020), March 1979, available from ORD Publications, CERL, Environmental Protection Agency, Cincinnati, Ohio 45268. For approved analytical procedures for metals, the technique applicable to total metals must be used.

Subp. 4. EPA microbiological. "EPA microbiological" means Microbiological Methods for Monitoring the Environment, Water and Wastes, United States Environmental Protection Agency, Environmental Monitoring and Support Laboratory, Cincinnati, Ohio 45268 (EPA-600/8-78-017), December 1978, available from ORD Publications, CERL, United States Environmental Protection Agency, Cincinnati, Ohio 45268.

Subp. 5. EPA Organochlorine methods. "EPA organochlorine methods" means Methods for Organochlorine Pesticides and Chlorophenoxy Acid Herbicides in Drinking Water and Raw Source Water, available from ORD Publications, CERL, United States Environmental Protection Agency, Cincinnati, Ohio 45268.

Subp. 6. Standard methods. "Standard methods" means Standard Methods for the Examination of Water and Wastewater, 14th Edition, American Public Health Association, 1015 15th Street NW, Washington, D.C. 20005.

Subp. 7. USGS 1972. "USGS 1972" means Techniques of Water Resources Investigation of the United States Geological Survey, Chapter A-3, "Methods of Analysis of Organic Substances in Water," Book 5, 1972, stock #2401-1227, available from Superintendent of Documents, United States Government Printing Office, Washington, D.C. 20402.

Subp. 8. USGS 1979. "USGS 1979" means Techniques of Water Resources Investigation of the United States Geological Survey, Chapter A-1, Methods for Determination of Inorganic Substances in Water and Fluvial Sediments, Book 5, 1979, stock #024-001-03177-9, available from Superintendent of Documents, United States Government Printing Office, Washington, D.C. 20402.

Statutory Authority: *MS s 144.381 to 144.388*

MINNESOTA RULES 1987

4207

PUBLIC WATER SUPPLIES 4720.1200

4720.1200 MICROBIOLOGICAL CONTAMINANT SAMPLING AND ANALYTICAL REQUIREMENTS.

Subpart 1. **Analysis.** Analyses for coliform bacteria shall be made for the purpose of determining compliance with part 4720.0500. Analyses shall be conducted in accordance with the analytical recommendations set forth in Standard Methods, Method 908A, Paragraphs 1, 2, and 3; or Method 908D, Table 908:I; or Method 909A; or EPA Microbiological Methods Part III, Section B 1.0 to 2.6.2, 2.7 to 2.7.2(c); or Part III, Section B 4.0 to 4.6.4(c), except that a standard sample size as referred to in items A and B shall be employed. See part 4720.1100, subparts 4 and 6 for complete title of reference sources.

A. The standard sample used in the membrane filter procedure shall be 100 milliliters.

B. The standard sample used in the five tube most probable number (MPN) procedure (fermentation tube method) shall be five times the standard portion. The standard portion is ten milliliters if compliance is to be determined according to the maximum contaminant level prescribed in part 4720.0500, subpart 3, and it is 100 milliliters if compliance is to be determined according to the maximum contaminant level prescribed in part 4720.0500, subpart 4. The samples shall be taken at points which are representative of the conditions within the distribution system.

Subp. 2. **Sampling frequency.** The supplier of water for a community water supply shall take samples to be analyzed for coliform density. The samples shall be taken at regular time intervals, and in number proportionate to the population served by the supply. In no event shall the frequency be less than as set forth below:

| Population served: | Minimum number of samples per month |
|--------------------|-------------------------------------|
| 25 to 1,000 | 1 |
| 1,001 to 2,500 | 2 |
| 2,501 to 3,300 | 3 |
| 3,301 to 4,100 | 4 |
| 4,101 to 4,900 | 5 |
| 4,901 to 5,800 | 6 |
| 5,801 to 6,700 | 7 |
| 6,701 to 7,600 | 8 |
| 7,601 to 8,500 | 9 |
| 8,501 to 9,400 | 10 |
| 9,401 to 10,300 | 11 |
| 10,301 to 11,100 | 12 |
| 11,101 to 12,000 | 13 |
| 12,001 to 12,900 | 14 |
| 12,901 to 13,700 | 15 |
| 13,701 to 14,600 | 16 |
| 14,601 to 15,500 | 17 |
| 15,501 to 16,300 | 18 |
| 16,301 to 17,200 | 19 |
| 17,201 to 18,100 | 20 |
| 18,101 to 18,900 | 21 |
| 18,901 to 19,800 | 22 |
| 19,801 to 20,700 | 23 |
| 20,701 to 21,500 | 24 |
| 21,501 to 22,300 | 25 |
| 22,301 to 23,200 | 26 |
| 23,201 to 24,000 | 27 |
| 24,001 to 24,900 | 28 |

MINNESOTA RULES 1987

4720.1200 PUBLIC WATER SUPPLIES

4208

| | |
|------------------------|-----|
| 24,901 to 25,000 | 29 |
| 25,001 to 28,000 | 30 |
| 28,001 to 33,000 | 35 |
| 33,001 to 37,000 | 40 |
| 37,001 to 41,000 | 45 |
| 41,001 to 46,000 | 50 |
| 46,001 to 50,000 | 55 |
| 50,001 to 54,000 | 60 |
| 54,001 to 59,000 | 65 |
| 59,001 to 64,000 | 70 |
| 64,001 to 70,000 | 75 |
| 70,001 to 76,000 | 80 |
| 76,001 to 83,000 | 85 |
| 83,001 to 90,000 | 90 |
| 90,001 to 96,000 | 95 |
| 96,001 to 111,000 | 100 |
| 111,001 to 130,000 | 110 |
| 130,001 to 160,000 | 120 |
| 160,001 to 190,000 | 130 |
| 190,001 to 220,000 | 140 |
| 220,001 to 250,000 | 150 |
| 250,001 to 290,000 | 160 |
| 290,001 to 320,000 | 170 |
| 320,001 to 360,000 | 180 |
| 360,001 to 410,000 | 190 |
| 410,001 to 450,000 | 200 |
| 450,001 to 500,000 | 210 |
| 500,001 to 550,000 | 220 |
| 550,001 to 600,000 | 230 |
| 600,001 to 660,000 | 240 |
| 660,001 to 720,000 | 250 |
| 720,001 to 780,000 | 260 |
| 780,001 to 840,000 | 270 |
| 840,001 to 910,000 | 280 |
| 910,001 to 970,000 | 290 |
| 970,001 to 1,050,000 | 300 |
| 1,050,001 to 1,140,000 | 310 |
| 1,140,001 to 1,230,000 | 320 |
| 1,230,001 to 1,320,000 | 330 |
| 1,320,001 to 1,420,000 | 340 |
| 1,420,001 to 1,520,000 | 350 |
| 1,520,001 to 1,630,000 | 360 |
| 1,630,001 to 1,730,000 | 370 |
| 1,730,001 to 1,850,000 | 380 |
| 1,850,001 to 1,970,000 | 390 |
| 1,970,001 to 2,060,000 | 400 |
| 2,060,001 to 2,270,000 | 410 |
| 2,270,001 to 2,510,000 | 420 |
| 2,510,001 to 2,750,000 | 430 |
| 2,750,001 to 3,020,000 | 440 |
| 3,020,001 to 3,320,000 | 450 |
| 3,320,001 to 3,620,000 | 460 |
| 3,620,001 to 3,960,000 | 470 |
| 3,960,001 to 4,310,000 | 480 |
| 4,310,001 to 4,690,000 | 490 |
| 4,690,001 or more | 500 |

Such sampling shall begin on the effective date of parts 4720.0100 to 4720.3900.

Based on a history of no coliform bacterial contamination and on a sanitary survey by the commissioner showing the water system to be supplied solely by a protected groundwater source and free of sanitary defects, a community water supply serving 25 to 1,000 persons, with written permission from the commissioner, may reduce this sampling frequency, except that in no case shall it be reduced to less than one per quarter. Such permission may be withdrawn at any time if changed conditions warrant monthly sampling.

Subp. 3. Special frequency for sampling noncommunity supply. The supplier of water for a noncommunity water supply shall sample for coliform bacteria at least once in each calendar quarter during which the supply provides water to the public. Such sampling shall begin before June 24, 1979. If the commissioner determines, on the basis of a sanitary survey which includes a determination of compliance with the Minnesota Water Well Construction Code, parts 4725.0100 to 4725.7600, that it is more appropriate for the supply to sample on a frequency other than quarterly, the commissioner shall impose a special sampling frequency. Such special frequency shall then be the frequency required under parts 4720.0100 to 4720.3900 and shall be confirmed or changed on the basis of subsequent surveys.

Subp. 4. Daily samples when coliform bacteria are found. Whenever any coliform bacteria are found in a single standard sample, at least two consecutive daily check samples shall be collected and examined from the same sampling point.

Additional check samples shall be collected daily until the results obtained from at least two consecutive daily check samples show no coliform bacteria in the case of the 100 milliliter membrane filter portions, or show no positive tubes in the case of the ten or 100 milliliter portions analyzed by the fermentation method.

The location at which the check samples were taken pursuant to this subpart shall not be eliminated from future sampling without approval of the commissioner.

Subp. 5. Determination of compliance. The results from all coliform bacterial analyses performed pursuant to parts 4720.0100 to 4720.3900, except those obtained from check samples as referred to in subpart 4 and special purpose samples as referred to in subpart 8, shall be used to determine compliance with the maximum contaminant level for coliform bacteria as established in part 4720.0500. Check samples shall not be included in calculating the total number of samples taken each month to determine compliance with part 4720.0500.

Subp. 6. Notification of supplier and commissioner of presence of coliform bacteria. When the presence of coliform bacteria in water taken from a particular sampling point has been confirmed by any check samples examined as directed in the second paragraph of subpart 4, the analytical laboratory shall notify the supplier and the commissioner within 24 hours.

Subp. 7. Notification to the public. As soon as a maximum contaminant level set forth in part 4720.0500 is exceeded, the supplier of water shall report to the commissioner and notify the public as prescribed in part 4720.3900.

Subp. 8. Special purpose samples. Special purpose samples, such as those taken to determine whether disinfection practices following pipe placement, replacement, or repair have been sufficient, shall not be used to determine compliance with subparts 2 and 3.

Subp. 9. Substitute use of free chlorine residual monitoring. A supplier of water of either a community or noncommunity water supply may, with the approval of the commissioner and based upon a sanitary survey, substitute the use of free chlorine residual monitoring for not more than 75 percent of the samples required to be taken by subparts 2 and 3. A supplier of water who is allowed to substitute chlorine residual sampling must take such samples at points

which are representative of the conditions within the distribution system at the frequency of at least four for each substituted microbiological sample required to be taken by subparts 2 and 3. There shall be at least daily determinations of chlorine residual. When the supplier of water exercises the option of substituting chlorine residual samples, he shall maintain no less than 0.2 mg/l free chlorine throughout the public water distribution system. When a particular sampling point has been shown to have a free chlorine residual less than 0.2 mg/l, the water at that location shall be retested as soon as practicable and in any event within one hour. If the original analysis is confirmed, this fact shall be reported to the commissioner within 48 hours. Also, if the analysis is confirmed, a sample for coliform bacterial analysis must be collected from that sampling point as soon as practicable and preferably within one hour, and the results of such analysis reported to the commissioner within 48 hours. Analyses for residual chlorine shall be made in accordance with Standard Methods for the Examination of Water and Wastewater, 13th Edition, pages 129 to 132. Compliance with the maximum contaminant levels for coliform shall be determined on the monthly mean or quarterly mean basis specified in part 4720.0500 including those samples taken as a result of failure to maintain the required chlorine residual level. The commissioner may withdraw his or her approval of the use of chlorine residual substitution at any time.

Statutory Authority: *MS s 144.381 to 144.388*

4720.1300 TURBIDITY SAMPLING AND ANALYTICAL REQUIREMENTS.

Subpart 1. Sampling. All public water supplies, whether community or noncommunity, which use water obtained in whole or in part from surface sources must be sampled for turbidity. Such samples shall be taken by suppliers at representative points of entry into the water distribution system at least once per day, for the purpose of making turbidity measurements to determine compliance with part 4720.0600.

The commissioner may reduce the sampling frequency for a noncommunity water supply if he determines that this reduced sampling frequency will not pose a risk to the public health and notifies the noncommunity water supply of this determination in writing. Such a reduction may be granted only if the noncommunity water supply practices disinfection and maintains an active disinfectant residual in the distribution system.

The measurement shall be made by the Nephelometric Method in accordance with the recommendations set forth in Standard Methods or EPA Chemical, Nephelometric Method, 180.1.1., as further described in part 4720.1100, subparts 3 and 6.

Sampling by community water supplies shall begin before the effective date of parts 4720.0100 to 4720.3900. Sampling by noncommunity water supplies shall begin before June 24, 1979.

Subp. 2. Results. If the result of a turbidity analysis indicates that the maximum allowable limit has been exceeded, the sampling and measurement shall be confirmed by resampling as soon as practicable and preferably within one hour. If the repeat sample confirms that the maximum allowable limit has been exceeded, the supplier of water shall report to the commissioner within 48 hours. The repeat sample shall be the sample used for the purpose of calculating the monthly average. If the monthly average of the daily samples exceeds the maximum allowable limit, or if the average of two samples taken on consecutive days exceeds five turbidity units, the supplier of water shall report to the commissioner as prescribed in part 4720.3700 and shall notify the public as prescribed in part 4720.3900.

Statutory Authority: *MS s 144.381 to 144.388*

4720.1400 INORGANIC CHEMICAL CONTAMINANT SAMPLING AND ANALYTICAL REQUIREMENTS.

Subpart 1. Analyses for inorganic chemical contaminant. Analyses for the purpose of determining compliance with part 4720.0700 are required as follows: Analyses for all community water supplies utilizing surface water sources shall be completed before June 24, 1978. These analyses shall be repeated at yearly intervals. Analyses for all community water supplies utilizing only groundwater sources shall be completed before June 24, 1979. These analyses shall be repeated at three year intervals. For noncommunity water supplies, whether supplied by surface or ground water sources, analyses for nitrate shall be completed before June 24, 1979. These analyses shall be repeated at least once every five years after the initial determination. The commissioner may order more frequent sampling depending upon the geological formation, the level of nitrate present and the size of the population being served.

Subp. 2. Data required. For the initial analyses required by subpart 1, data for surface waters acquired within one year prior to June 24, 1977, and data for ground waters acquired within three years prior to June 24, 1977, may be substituted at the discretion of the commissioner.

Subp. 3. Methods of analysis. Analyses conducted to determine compliance with part 4720.0700 shall be made in accordance with items A to J. See part 4720.1100 for complete title of reference sources.

A. Arsenic: EPA Chemical, Method 206.2, or Method 206.3, or Method 206.4; or Standard Methods, Method 404-A and 404-B(4), or Method 301.A VII; or USGS 1979, Method I-1062-78; or ASTM, Method D-2972-78A, or D-2972-78B.

B. Barium: EPA Chemical, Method 208.1, or 208.2; or Standard Methods, Method 301-A IV.

C. Cadmium: EPA Chemical, Method 213.1, or 213.2; or Standard Methods, Method 301-A II or III; or ASTM, Method 3447-78A.

D. Chromium: EPA Chemical, Method 218.1, or 218.2; or Standard Methods, Method 301-A II or III; or ASTM, Method D-1687-77D.

E. Fluoride: EPA Chemical, Method 340.1 or 340.2, or 340.3; or Standard Methods, Method 414-A, or 414-B, or 414-C, or 603; or USGS 1979, Method I-3325-78; or ASTM, Method D-1179-72A, or D-1179-72B; or Industrial Method #129-71W, Fluoride in Water and Wastewater, Technicon Industrial Systems, Tarrytown, New York 10591, December 1972; or Industrial Method #380-75WE, Automated Electrode Method, Fluoride in Water and Wastewater, Technicon Industrial Systems, Tarrytown, New York, February 1976.

F. Lead: EPA Chemical, Method 239.1 or 239.2; or Standard Methods, Method 301-A II or III; or ASTM, Method D-3559-79A or B.

G. Mercury: EPA Chemical, Method 245.1 or 245.2; or Standard Methods, Method 301-A VI; or ASTM, Method D-3223-79.

H. Nitrate: EPA Chemical, Method 352.1, or 353.1 or 353.2 or 353.3; or Standard Methods, Method 419-D, or 419-C, or 605; or ASTM, Method D-992-71, or D-3867-79A or D-3867-79B.

I. Selenium: EPA Chemical, Method 270.2 or 270.3; or Standard Methods, Method 301-A VII; or USGS 1979, Method I-1667-78; or ASTM, Method D-3859-79.

J. Silver: EPA Chemical, Method 272.1 or 272.2; or Standard Methods, Method 301-A II.

Subp. 4. Notification of commissioner when maximum contaminant level exceeded. If the result of an analysis made pursuant to subpart 1 indicates that the level of any contaminant listed in part 4720.0700 exceeds the maximum contaminant level, the supplier of water shall report to the commissioner within

4720.1400 PUBLIC WATER SUPPLIES

4212

seven days from the time he receives the results and he shall collect and submit for analysis three additional samples taken at the same sampling point within one month from the time the commissioner is notified.

Subp. 5. When average of analyses exceeds maximum contaminant level. When the average of four analyses made pursuant to subpart 4, rounded to the same number of significant figures as the maximum contaminant level for the substance in question, exceeds the maximum contaminant level prescribed in part 4720.0700, the supplier of water shall notify the commissioner within 48 hours pursuant to part 4720.3700 and give notice to the public pursuant to part 4720.3900. Monitoring after public notification shall be at a frequency designated by the commissioner and shall continue until the maximum contaminant level has not been exceeded in two successive samples or until a new monitoring schedule prescribed as a condition to a variance, exemption, or enforcement action shall become effective.

Subp. 6. Compliance. The provisions of subparts 4 and 5 notwithstanding, compliance with the maximum contaminant level for nitrate shall be determined on the basis of the mean of two analyses. When a level exceeding the maximum contaminant level for nitrate is found, a second analysis shall be initiated within 24 hours, and if the mean of the two analyses exceeds the maximum contaminant level, the supplier of water shall report his findings to the commissioner within 48 hours pursuant to part 4720.3700 and shall notify the public pursuant to part 4720.3900.

Statutory Authority: *MS s 144.381 to 144.388*

4720.1500 ORGANIC CHEMICAL CONTAMINANT SAMPLING AND ANALYTICAL REQUIREMENTS.

Subpart 1. Analysis. An analysis of substances for the purpose of determining compliance with part 4720.0800 shall be made as follows:

A. For all community water supplies utilizing surface water sources, analyses shall be completed before June 24, 1978. Samples analyzed shall be collected during the period of the year designated by the commissioner as the period when contamination by pesticides is most likely to occur. These analyses shall be repeated at intervals specified by the commissioner but in no event less frequently than at three-year intervals.

B. For community water supplies utilizing only groundwater sources, analyses shall be completed by those supplies specified by the commissioner.

Subp. 2. Analytical requirements. Analytical requirements for compliance with part 4720.0800, subpart 1, items A and B shall be as described in items A and B:

A. Analyses made to determine compliance with part 4720.0800, subpart 1, item A shall be made in accordance with EPA Organochlorine Methods; or Standard Methods, Method 509-A; or ASTM, Method D-3086-79; or USGS 1972, Gas Chromatographic Methods for Analysis of Organic Substances in Water, Chapter A-3. See part 4720.1100 for complete title of reference sources.

B. Analyses made to determine compliance with part 4720.0800, subpart 1, item B shall be conducted in accordance with EPA Organochlorine Methods; or Standard Methods, Method 509-B; or ASTM, Method D-3478-79; or USGS 1972, Gas Chromatographic Methods for Analysis of Organic Substances in Water, Chapter A-3. See part 4720.1100 for complete title of reference sources.

Subp. 3. Notification of commissioner when maximum contaminant level exceeded. If the result of an analysis made pursuant to subpart 1 indicates that the level of any contaminant listed in part 4720.0800 exceeds the maximum contaminant level, the supplier of water shall report to the commissioner within seven days and collect and submit for analysis three additional samples taken at

the same sampling point within one month from the time the commissioner is notified.

Subp. 4. Average of analyses exceeds maximum contaminant level. When the average of four analyses made pursuant to part 4720.1400, subpart 3, rounded to the same number of significant figures as the maximum contaminant level for the substance in question, exceeds the maximum contaminant level, the supplier of water shall report to the commissioner pursuant to part 4720.3700 and give notice to the public pursuant to 4720.3900. Monitoring after public notification shall be at a frequency designated by the commissioner and shall continue until the maximum contaminant level has not been exceeded in two successive samples or until a monitoring schedule as a condition to a variance or exemption or enforcement action shall become effective.

Statutory Authority: *MS s 144.381 to 144.388*

4720.1600 TRIHALOMETHANE SAMPLING.

Subpart 1. Requirements. Total trihalomethanes sampling, analytical, and other requirements shall be as described in subparts 2 to 10.

Subp. 2. Community water supplies serving a population of 10,000 or more. Community water supplies which serve a population of 10,000 or more individuals and which add a disinfectant (oxidant) to the water in any part of the drinking water treatment process shall analyze for total trihalomethanes in accordance with this part. For systems serving 75,000 or more individuals, sampling and analyses shall begin not later than the effective date of parts 4720.0100 to 4720.3900. For systems serving 10,000 to 74,999 individuals, sampling and analyses shall begin not later than January 1, 1983. For the purpose of this part, the minimum number of samples required to be taken by the system shall be based on the number of treatment plants used by the system, except that multiple wells drawing raw water from a single aquifer are considered one treatment plant for determining the minimum number of samples. All samples taken within an established frequency shall be collected within a 24-hour period.

Subp. 3. Community water supplies utilizing surface water sources. For all community water supplies utilizing surface water sources in whole or in part, and for all community water supplies utilizing only groundwater sources that have not been determined by the commissioner to qualify for the monitoring requirements of subparts 6 and 7, analyses for total trihalomethanes shall be performed at quarterly intervals on at least four water samples for each treatment plant used by the supply. At least 25 percent of the samples shall be taken at locations within the distribution system reflecting the maximum residence time of the water in the system. The remaining 75 percent shall be taken at representative locations in the distribution system, taking into account number of persons served, different sources of water and different treatment methods employed. The results of all analyses per quarter shall be arithmetically averaged and reported to the commissioner within 30 days of the supply's receipt of such results. All samples collected shall be used in the computation of the average, unless the analytical results are invalidated for technical reasons. Sampling and analyses shall be conducted in accordance with the methods listed in subpart 9.

Subp. 4. Written request for reduction in monitoring frequency for community water system. Upon the written request of a community water system, the monitoring frequency required by subpart 3 may be reduced by the commissioner to a minimum of one sample analyzed for total trihalomethanes per quarter taken at a point in the distribution system reflecting the maximum residence time of the water in the system, upon a written determination by the commissioner that the data from at least one year of monitoring in accordance with subpart 3 and local conditions demonstrate that total trihalomethane concentrations will be consistently below the maximum contaminant level.

Subp. 5. Reduced monitoring and change in analysis. If at any time during

which the reduced monitoring frequency prescribed under subpart 4 applies, the results from any analysis exceed 0.10 milligrams per liter of total trihalomethanes and such results are confirmed by at least one check sample taken promptly after such results are received, or if the supply makes any significant change to its source of water or treatment program, the supply shall immediately begin monitoring in accordance with the requirements of subpart 3 and shall continue that monitoring for at least one year before the frequency may be reduced again.

Subp. 6. Written request for reduction in monitoring frequency in communities using ground water sources. Upon written request to the commissioner, a community water supply utilizing only groundwater sources may seek to have the monitoring frequency required by subpart 3 reduced to a minimum of one sample for maximum total trihalomethane potential per year for each treatment plant used by the supply taken at a point in the distribution system reflecting maximum residence time of the water in the system. The supply shall submit to the commissioner the results of at least one sample analyzed for maximum total trihalomethane potential for each treatment plant used by the supply taken at a point in the distribution system reflecting the maximum residence time of the water in the system. The supply's monitoring frequency may only be reduced upon a written determination by the commissioner that, based upon the data submitted by the supply, the supply has a maximum total trihalomethane potential of less than 0.10 milligrams per liter and that, based upon an assessment of the local conditions of the supply, the supply is not likely to approach or exceed the maximum contaminant level for total trihalomethanes. All samples collected shall be used for determining whether the supply must comply with the monitoring requirements of subparts 3 to 5, unless the analytical results are invalidated for technical reasons. Sampling and analyses shall be conducted in accordance with the methods listed in subpart 9.

Subp. 7. Change in analysis, on a reduced monitoring of ground water sources. If at any time during which the reduced monitoring frequency prescribed under subpart 6 applies, the results from any analysis taken by the supply for maximum total trihalomethane potential are equal to or greater than 0.10 milligrams per liter, and those results are confirmed by at least one check sample taken promptly after such results are received, the supply shall immediately begin monitoring in accordance with the requirements of subparts 3 to 5. The monitoring shall continue for at least one year before the frequency may be reduced again. In the event of any significant change to the supply's raw water or treatment program, the supply shall immediately analyze an additional sample for maximum total trihalomethane potential taken at a point in the distribution system reflecting maximum residence time of the water in the system for the purpose of determining whether the supply must comply with the monitoring requirements of subparts 3 to 5.

Subp. 8. Compliance. Compliance with part 4720.0800, subpart 2 shall be determined based on a running annual average of quarterly samples collected by the supply as prescribed in subparts 3 and 4. If the average of samples covering any 12-month period exceeds the maximum contaminant level prescribed in part 4720.0800, subpart 2, the supplier of water shall report to the state pursuant to part 4720.3700 and notify the public pursuant to part 4720.3900. Monitoring after public notification shall be at a frequency designated by the commissioner and shall continue until a monitoring schedule as a condition to a variance, exemption or enforcement action shall become effective.

Subp. 9. Methods of sampling and analyses. Sampling and analyses made pursuant to this part shall be conducted by one of the following methods:

A. The Analysis of Trihalomethanes in Finished Waters by the Purge and Trap Method, Method 501.1, Environmental Monitoring and Support Laboratory, United States Environmental Protection Agency, Cincinnati, Ohio 45268.

B. The Analysis of Trihalomethanes in Drinking Water by Liquid/

Liquid Extraction, Method 501.2, Environmental Monitoring and Support Laboratory, United States Environmental Protection Agency, Cincinnati, Ohio 45268.

Samples for total trihalomethane shall be dechlorinated upon collection to prevent further production of trihalomethanes, according to the procedures described in items A and B. Samples for maximum total trihalomethane potential should not be dechlorinated, and should be held for seven days at 25 degrees Celsius prior to analysis, according to the procedures described in items A and B.

Subp. 10. Commissioner approval of modification. Before a community water supply makes any significant modifications to its existing treatment process for the purposes of achieving compliance with part 4720.0800, subpart 2, such supply must submit to the commissioner and obtain the commissioner's approval of a detailed plan setting forth its proposed modification and those safeguards that it will implement to ensure that the bacteriological quality of the drinking water served by such supply will not be adversely affected by such modification. Each supply shall comply with the provisions set forth in the plan as approved. At a minimum, an approved plan shall require the system modifying its disinfection practice to:

A. evaluate the water supply for sanitary defects and evaluate the source water for biological quality;

B. evaluate its existing treatment practices and consider improvements that will minimize disinfectant demand and optimize finished water quality throughout the distribution system;

C. provide baseline water quality survey data of the distribution system (such data shall include the results from monitoring for coliform and fecal coliform bacteria, standard plate counts at 35 degrees Celsius and 20 degrees Celsius, phosphate, ammonia nitrogen, and total organic carbon);

D. conduct additional monitoring to assure continued maintenance of optimal biological quality in finished water, for example, when chloramines are introduced as disinfectants or when prechlorination is being discontinued; and

E. demonstrate an active disinfectant residual throughout the distribution system at all times during and after the modification.

Statutory Authority: *MS s 144.381 to 144.388*

4720.1700 MONITORING REQUIREMENTS FOR GROSS ALPHA PARTICLE ACTIVITY, RADIUM-226, AND RADIUM-228.

Subpart 1. Initial sampling. Initial sampling to determine compliance with part 4720.0900, subpart 2, shall begin before June 24, 1979, and the analysis shall be completed before June 24, 1980. Compliance shall be based on the analysis of an annual composite of four consecutive quarterly samples or the average of the analyses of four samples obtained at quarterly intervals.

A gross alpha particle activity measurement may be substituted for the required radium-226 and radium-228 analyses provided that the measured gross alpha particle activity does not exceed five pCi per liter at a confidence level of 95 percent (1.65σ where σ is the standard deviation of the net counting rate of the sample).

In localities where radium-228 may be present in drinking water, analyses for radium-226 and/or radium-228 are required when the gross alpha particle activity exceeds two pCi per liter at a confidence level of 95 percent.

When the gross alpha particle activity exceeds five pCi per liter, the same or an equivalent sample shall be analyzed for radium-226. If the concentration of radium-226 exceeds three pCi per liter, the same or an equivalent sample shall be analyzed for radium-228.

Subp. 2. Monitoring of water. Suppliers of water shall monitor at least once every four years following the procedure required by subpart 1. When an annual

record taken in conformance with subpart 1 has established that the average annual concentration is less than half the maximum contaminant levels established by part 4720.0900, subpart 2, analysis of a single sample may be substituted for the quarterly sampling procedure required by subpart 1.

More frequent monitoring shall be conducted when ordered by the commissioner in the vicinity of mining or other operations which may contribute alpha particle radioactivity to either surface or ground water sources of drinking water.

A supplier of water shall monitor in conformance with subpart 1 within one year of the introduction of a new water source for a community water supply. More frequent monitoring shall be conducted when ordered by the commissioner in the event of possible contamination or when changes in the distribution system or treatment process occur which may increase the concentration of radioactivity in finished water.

A community water supply using two or more sources having different concentrations of radioactivity shall monitor source water, in addition to water from a free-flowing tap, when ordered by the commissioner.

Monitoring for compliance with part 4720.0900, subpart 2 after the initial period need not include radium-228 except when required by the commissioner, provided that the average annual concentration of radium-228 has been assayed at least once using the quarterly sampling procedure required by subpart 1.

Suppliers of water shall conduct annual monitoring of any community water supply in which the radium-226 concentration exceeds three pCi per liter, when ordered by the commissioner.

Subp. 3. Notification of commissioner of maximum contaminant level exceeded. If the average annual maximum contaminant level for gross alpha particle activity or total radium as set forth in part 4720.0900, subpart 2 is exceeded, the supplier of a community water system shall give notice to the commissioner pursuant to part 4720.3700 and notify the public as required by part 4720.3900. Monitoring at quarterly intervals shall be continued until the annual average concentration no longer exceeds the maximum contaminant level or until a monitoring schedule as a condition to a variance, exemption, or enforcement action shall become effective.

Statutory Authority: *MS s 144.381 to 144.388*

4720.1800 MONITORING REQUIREMENTS FOR MAN-MADE RADIOACTIVITY.

Subpart 1. Monitoring. Before June 24, 1979, community water supplies using surface sources and serving more than 100,000 persons, and such other community water supplies as are designated by the commissioner shall be monitored for compliance with part 4720.0900, subpart 3 by analysis of a composite of four consecutive quarterly samples or analysis of four quarterly samples. Compliance with part 4720.0900, subpart 3 may be assumed without further analysis if the average annual concentration of gross beta particle activity is less than 50 pCi per liter and if the average annual concentrations of tritium and strontium-90 are less than those listed in part 4720.0900, subpart 3, item C, provided that if both radio nuclides are present the sum of their annual dose equivalents to bone marrow shall not exceed four millirem/year.

If the gross beta particle activity exceeds 50 pCi per liter, an analysis of the sample must be performed to identify the major radioactive constituents present and the appropriate organ and total body doses shall be calculated to determine compliance with part 4720.0900, subpart 3.

Suppliers of water shall conduct additional monitoring, as ordered by the commissioner, to determine the concentration of man-made radioactivity in principal watersheds designated by the commissioner.

At the discretion of the commissioner suppliers of water utilizing only ground waters may be required to monitor for man-made radioactivity.

After the initial analysis required by this subpart, these suppliers shall monitor at least every four years following the procedure given in this subpart.

Subp. 2. Quarterly monitoring. Before June 24, 1979, the supplier of any community water supply which is found by the commissioner to be utilizing waters contaminated by effluents from nuclear facilities shall initiate quarterly monitoring for gross beta particle and iodine-131 radioactivity and annual monitoring for strontium-90 and tritium.

Quarterly monitoring for gross beta particle activity shall be based on the analysis of monthly samples. If the gross beta particle activity in a sample exceeds 15 pCi per liter, the same or an equivalent sample shall be analyzed for strontium-89 and cesium-134. If the gross beta particle activity exceeds 50 pCi per liter, an analysis of the sample must be performed to identify the major radioactive constituents present and the appropriate organ and total body doses shall be calculated to determine compliance with part 4720.0900, subpart 3.

For iodine-131, a composite of five consecutive daily samples shall be analyzed once each quarter. As ordered by the commissioner, more frequent monitoring shall be conducted when iodine-131 is identified in the finished water.

Annual monitoring for strontium-90 and tritium shall be conducted by means of the analysis of four quarterly samples.

The commissioner may allow the substitution of environmental surveillance data taken in conjunction with a nuclear facility for direct monitoring of man-made radioactivity by the supplier of water where the commissioner determines such data is applicable to a particular community water supply.

Subp. 3. Notification of commissioner of annual maximum contaminant level exceeded. If the average annual maximum contaminant level for man-made radioactivity set forth in part 4720.0900, subpart 3 is exceeded, the supplier of a community water supply shall give notice to the commissioner pursuant to part 4720.3700 and to the public as required by part 4720.3900. Monitoring at monthly intervals shall be initiated and continued until the concentration no longer exceeds the maximum contaminant level or until a monitoring schedule as a condition to a variance, exemption, or enforcement action shall become effective.

Statutory Authority: *MS s 144.381 to 144.388*

4720.1900 ANALYTICAL METHODS.

Subpart 1. Measurements. Measurements made to determine compliance with part 4720.0900 shall be made in accordance with the following methods:

A. Gross Alpha and Beta: Section 302, Gross Alpha and Beta Radioactivity in Water "Standard Methods for the Examination of Water and Wastewater," 13th edition, American Public Health Association, New York, N.Y., 1975.

B. Total Radium: Section 304, Radium in Water by Precipitation, *ibid.*

C. Radium-226: Section 305, Radium-226 by Radon in Water, *ibid.*

D. Strontium-89, 90: Section 303, Total Strontium and Strontium-90 in Water, *ibid.*

E. Tritium: Section 306, Tritium in Water, *ibid.*

F. Cesium-134: ASTM D-2459, Gamma Spectrometry in Water, 1975 "Annual Book of ASTM Standards," Water and Atmospheric Analysis, Part 31, American Society for Testing and Materials, Philadelphia, PA, 1975.

G. Uranium: ASTM D-2907, Microquantities of Uranium in Water by Fluorometry, *ibid.*

When the identification and measurement of radionuclides other than those listed above is required, the following references are to be used, except in cases where alternative methods have been approved in accordance with part 4720.2000.

H. "Procedures for Radiochemical Analysis of Nuclear Reactor Aqueous Solutions." H. L. Krieger and S. Gold, EPA-R4-73-014. USEPA, Cincinnati, Ohio, May 1973.

I. HASL Procedure Manual, edited by John H. Harley. HASL 300, ERDA Health and Safety Laboratory, New York, N.Y., 1973.

Subp. 2. **Detection limit of radioanalysis.** For the purpose of monitoring radioactivity concentrations in drinking water, the required sensitivity of the radioanalysis is defined in terms of a detection limit. The detection limit shall be that concentration which can be counted with a precision of plus or minus 100 percent at the 95 percent confidence level (1.96σ where σ is the standard deviation of the net counting rate of the sample).

To determine compliance with part 4720.0900, subpart 2, item A the detection limit shall not exceed one pCi per liter. To determine compliance with part 4720.0900, subpart 2, item B, the detection limit shall not exceed three pCi per liter.

To determine compliance with part 4720.0900, subpart 3 the detection limits shall not exceed the concentrations listed in subpart 3.

Subp. 3. **Detection limits for man-made beta particle and photon emitters.**

| Radionuclide | Detection Limit |
|---------------------|------------------------------|
| Tritium | 1,000 pCi per liter |
| Strontium-89 | 10 pCi per liter |
| Strontium-90 | 2 pCi per liter |
| Iodine-131 | 1 pCi per liter |
| Cesium-134 | 10 pCi per liter |
| Gross beta | 4 pCi per liter |
| Other radionuclides | 1/10 of the applicable limit |

To judge compliance with the maximum contaminant levels listed in part 4720.0900, subparts 2 and 3, averages of data shall be used and shall be rounded to the same number of significant figures as the maximum contaminant level for the substance in question.

Statutory Authority: *MS s 144.381 to 144.388*

4720.2000 ALTERNATIVE ANALYTICAL TECHNIQUES.

With the written permission of the commissioner, an alternative analytical technique may be employed. An alternative technique shall be acceptable only if it is substantially equivalent to the prescribed test in both precision and accuracy as it relates to the determination of compliance with any maximum contaminant level. The use of the alternative analytical technique shall not decrease the frequency of monitoring required by these rules.

Statutory Authority: *MS s 144.381 to 144.388*

4720.2100 APPROVED LABORATORIES.

For the purpose of determining compliance with parts 4720.1000 to 4720.1900, samples may be considered only if they have been analyzed by a laboratory approved by the commissioner, except that measurements for temperature, pH, turbidity, and free chlorine residual may be performed by any person acceptable to the commissioner.

Statutory Authority: *MS s 144.381 to 144.388*

4720.2200 MONITORING CONSECUTIVE SYSTEMS.

When a public water supply provides water to one or more other public water supplies, the monitoring requirements imposed by parts 4720.1000 to 4720.1900 may be superseded by a special monitoring schedule prescribed by the commis-

sioner. Such a special monitoring schedule may be imposed to the extent that the interconnection justifies treating them as a single supply for monitoring purposes, and is enforceable just as any other monitoring requirement imposed by these rules. Such a special monitoring schedule shall include an agreement which names the supply or supplies responsible for monitoring, reporting, giving public notice, and maintaining records.

Statutory Authority: *MS s 144.381 to 144.388*

4720.2300 ADDITIONAL MONITORING REQUIREMENTS.

The commissioner may impose additional monitoring requirements if the results of a sanitary survey indicate that a public health risk may exist. The commissioner may impose a requirement for more frequent sampling if the analytical results of water tests show that a previously measured contaminant is approaching a maximum contaminant level as prescribed in parts 4720.0400 to 4720.0900.

Statutory Authority: *MS s 144.381 to 144.388*

4720.2400 SPECIAL MONITORING FOR SODIUM.

Subpart 1. Samples. Community public water supplies shall collect and analyze one sample per treatment plant at the entry point of the distribution system for the determination of sodium concentration levels. Samples must be collected and analyzed annually for supplies utilizing surface water sources in whole or in part, and at least every three years for supplies utilizing solely groundwater sources. The minimum number of samples required to be taken by the supply shall be based on the number of treatment plants used by the supply, except that multiple wells drawing raw water from a single aquifer will be considered one treatment plant for determining the minimum number of samples.

Subp. 2. Results. The supplier of water shall report the results of the analyses for sodium within the first ten days of the month following the month in which the sample results were received or within the first ten days following the end of the required monitoring period as stipulated by the commissioner whichever of these is first. If more than annual sampling is required, the supplier shall report the average sodium concentration within ten days of the month following the month in which the analytical results of the last sample used for the annual average were received.

Subp. 3. Analyses. Analyses for sodium shall be performed by the flame photometric method in accordance with the procedures described in Standard Methods, Method 320A; or EPA Chemical, Method 273.1 or 273.2; or ASTM, Method D-1428-64A. See part 4720.1100 for complete title of reference sources.

Statutory Authority: *MS s 144.381 to 144.388*

4720.2500 SPECIAL MONITORING FOR CORROSIVITY CHARACTERISTICS.

Subpart 1. Samples. Community public water supplies shall collect samples from a representative entry point to the water distribution system for the purpose of analysis to determine the corrosivity characteristics of the water.

The supplier shall collect for analysis for each treatment plant using surface water sources in whole or in part, one sample during midwinter and one sample during midsummer. The supplier of the water shall collect for analysis one sample per treatment plant for each treatment plant using ground water sources. The minimum number of samples required to be taken by the supply shall be based on the number of treatment plants used by the supply, except that multiple wells drawing raw water from a single aquifer may be considered one treatment plant for determining the minimum number of samples.

Determination of the corrosivity characteristics of the water shall include

measurement of pH, calcium hardness, alkalinity, temperature, total dissolved solids or total filterable residue, and calculation of the Langelier Index in accordance with subpart 3. The determination of corrosivity characteristics shall only include one round of sampling. One round of sampling consists of two samples per treatment plant for surface water and one sample per treatment plant for ground water sources.

Subp. 2. Results. The supplier of water shall report the results of the analyses for the corrosivity characteristics within the first ten days of the month following the month in which the sample results were received. If more frequent sampling is required the supplier can accumulate the data and report each value within ten days of the month following the month in which the analytical results of the last sample were received.

Subp. 3. Analysis. Analyses conducted to determine the corrosivity of the water shall be made in accordance to the methods described in items A to F. See part 4720.1100 for complete title of reference sources.

A. Langelier Index: Standard Methods, Method 203.

B. Total Filterable Residue: Standard Methods, Method 208B; or EPA Chemical, Method 160.1.

C. Temperature: Standard Methods, Method 212.

D. Calcium: Standard Methods, Method 306C; or ASTM, Method D-1126-67B.

E. Alkalinity: Standard Methods, Method 403; or ASTM, Method D-1067-70B; or EPA Chemical, Method 310.1.

F. pH: Standard Methods, Method 424; or EPA Chemical, Method 150.1; or ASTM, Method D-1293-78 A or B.

Subp. 4. Report of construction materials in the distribution system. Community water supplies shall identify whether the following construction materials are present in their distribution system and report to the commissioner the existence of any of the following materials:

A. lead from piping, solder, caulking, interior lining of distribution mains, alloys, and home plumbing;

B. copper from piping and alloys, service lines, and home plumbing;

C. galvanized piping, service lines, and home plumbing;

D. ferrous piping materials such as cast iron and steel;

E. asbestos cement pipe;

F. vinyl-lined asbestos cement pipe; or

G. coal tar lined pipes and tanks.

Statutory Authority: *MS s 144.381 to 144.388*

4720.2600 VARIANCES.

Subpart 1. General conditions. The commissioner may grant one or more variances from a maximum contaminant level prescribed in parts 4720.0400 to 4720.0900 or from a treatment required by these rules, pursuant to authority granted in Laws of Minnesota 1977, chapter 66, section 3, clause (e), according to the procedure described in this part.

Subp. 2. Request for variance. A supplier may request a variance whenever he determines that his supply is exceeding or will exceed a maximum contaminant level. A supplier who has not requested a variance or has not taken corrective action to bring his supply into compliance by the date specified in the notification of violation shall be subject to the penalties of Laws of Minnesota 1977, chapter 66, section 3, clause (e).

Subp. 3. Matters to be considered. In deciding whether to grant a variance from a maximum contaminant level, the commissioner shall consider: the availa-

bility and effectiveness of treatment methods for the contaminant for which the variance is requested; and cost and other economic considerations such as implementing treatment, improving the quality of the source water or using an alternative source.

Subp. 4. Specific conditions for variance. The commissioner may grant a variance from a maximum contaminant level upon finding that:

A. because of the characteristics of the raw water sources which are reasonably available to the supply, the supply cannot meet the requirements respecting the maximum contaminant levels prescribed in parts 4720.0400 to 4720.0900 despite the application of the best known and economically feasible technology for treatment or other means; and

B. the variance will not result in an unreasonable risk to health.

The commissioner may grant a variance from any required treatment upon finding that the supply has demonstrated that such treatment is not necessary to meet a maximum contaminant level or to protect the health of persons, because of the nature of the raw water source of the supply.

Statutory Authority: *MS s 144.381 to 144.388*

4720.2700 APPLICATION PROCEDURE FOR VARIANCE.

A request for a variance shall be submitted to the commissioner in writing and shall contain the following information:

A. The nature and duration of the variance being requested.

B. Relevant analytical results of water quality sampling of the supply, including results of relevant tests conducted pursuant to the requirements of parts 4720.0100 to 4720.3900.

C. For any request for a variance from a maximum contaminant level, the notice shall also contain:

(1) An explanation in full and evidence of the best available treatment.

(2) Economic and legal factors relevant to the ability to comply.

(3) Analytical results of raw water quality relevant to the variance request.

(4) A proposed compliance schedule, including the date each step toward compliance will be achieved. Such a schedule shall include as a minimum the following dates:

(a) a date by which arrangement for alternative raw water source or improvement of existing raw water source will be completed;

(b) a date for initiation of the connection of the alternative raw water source or improvement of existing raw water source; and

(c) a date by which final compliance is to be achieved.

(5) A plan for the provision of safe drinking water in the case of an excessive rise in the contaminant level for which the variance is requested.

(6) A plan for interim control measures during the effective period of variance.

D. For any request for a variance from a required treatment, the notice shall include a statement that the supply will perform monitoring and other reasonable requirements prescribed by the commissioner as a condition to the variance.

E. Such other information as the commissioner may require.

F. Any information which the supplier believes is pertinent to the request.

Statutory Authority: *MS s 144.381 to 144.388*

4720.2800 DISPOSITION OF A REQUEST FOR A VARIANCE.

Upon receipt of an application for a variance the commissioner shall initiate, within 90 days, the procedure for a contested case. Notice and opportunity for hearing shall be given according to Minnesota Statutes, chapter 14 and the rules of the Office of Administrative Hearings.

The commissioner shall within one year after the variance is granted, impose a schedule for compliance with parts 4720.0100 to 4720.3900, after notice and opportunity for hearing have been given.

Statutory Authority: *MS s 144.381 to 144.388*

4720.2900 TERMINATION OF A VARIANCE.

A variance from a maximum contaminant level may be terminated by the commissioner when the supply comes into compliance with the applicable rule, and may be terminated by the commissioner upon a finding that the supply has failed to comply with any requirement of a final schedule imposed by the commissioner pursuant to these rules.

A variance from a required treatment may be terminated at any time upon a finding by the commissioner that the nature of the raw water source is such that the required treatment for which the variance was granted is necessary to protect the health of persons, or upon a finding by the commissioner that the supply has failed to comply with monitoring and other requirements prescribed as a condition to the granting of the variance.

Statutory Authority: *MS s 144.381 to 144.388*

4720.3000 COMPLIANCE WITH VARIANCE.

A compliance schedule imposed by the commissioner pursuant to the grant of a variance shall be enforceable as if it were a rule of the commissioner.

Statutory Authority: *MS s 144.381 to 144.388*

4720.3100 EXEMPTIONS.

The commissioner may grant one or more exemptions from a maximum contaminant level prescribed in parts 4720.0400 to 4720.0900 or from a treatment required by these rules, pursuant to authority granted in Laws of Minnesota 1977, chapter 66, section 3, clause (e), according to the procedure described below.

A supplier may request an exemption whenever he determines that his supply is exceeding or will exceed a maximum contaminant level. A supplier who has not requested an exemption or has not taken corrective action to bring his supply into compliance by the date specified in the notification of violation shall be subject to the penalties of Laws of Minnesota 1977, chapter 66, section 3, clause (e).

The commissioner may grant an exemption from a maximum contaminant level or from a required treatment:

A. after having considered the following: construction, installation, or modification of treatment equipment or systems; the time needed to put into operation a new treatment facility to replace an existing supply which is not in compliance; economic feasibility of compliance; and

B. upon finding that, due to compelling factors (which may include economic factors), the supply is unable to comply with such contaminant level or required treatment; the supply was in operation on the date on which such contaminant level or required treatment went into effect; and the granting of the exemption will not result in an unreasonable risk to health.

Statutory Authority: *MS s 144.381 to 144.388*

4720.3200 APPLICATION PROCEDURE FOR EXEMPTION.

A request for an exemption shall be submitted to the commissioner in writing and shall contain the following information:

- A. the nature and duration of the exemption being requested;
- B. relevant analytical results of water quality sampling of the supply, including results of relevant tests conducted pursuant to the requirements of parts 4720.0100 to 4720.3900.
- C. an explanation of the compelling factors such as time or economic factors which prevent the supply from complying with a maximum contaminant level or required treatment on the effective date of the applicable standard;
- D. a proposed compliance schedule, including the date when each step toward compliance will be achieved;
- E. such other information as the commissioner may require; and
- F. any other information which the applicant believes is pertinent to the request.

Statutory Authority: *MS s 144.381 to 144.388*

4720.3300 DISPOSITION OF A REQUEST FOR AN EXEMPTION.

Upon receipt of an application for an exemption the commissioner shall initiate within 90 days, the procedure for a contested case. Notice and opportunity for hearing shall be given according to Minnesota Statutes, chapter 14 and the rules of the Office of Administrative Hearings.

The commissioner shall within one year after the exemption is granted, impose a schedule for compliance with parts 4720.0100 to 4720.3900 after notice and opportunity for hearing have been given.

Statutory Authority: *MS s 144.381 to 144.388*

4720.3400 TERMINATION OF AN EXEMPTION.

An exemption may be terminated by the commissioner when the supply comes into compliance with the applicable rule, and may be terminated by the commissioner of health upon a finding by the commissioner that the supply has failed to comply with any requirement of a final schedule imposed pursuant to parts 4720.0100 to 4720.3900.

Statutory Authority: *MS s 144.381 to 144.388*

History: *L 1977 c 305 s 39*

4720.3500 COMPLIANCE WITH EXEMPTION.

Any compliance schedule issued pursuant to an exemption shall require compliance with parts 4720.0100 to 4720.3900 before January 1, 1981. Compliance with the requirements of revised federal regulations will have to be achieved within seven years of the date on which such federal regulations become effective.

If the supply which seeks the exemption has entered into an enforceable agreement to become a part of a regional system, as determined by the commissioner, the compliance schedule shall require compliance by the supply with each maximum contaminant level or required treatment prescribed by parts 4720.0100 to 4720.3900 before January 1, 1983. For such a supply (which will become part of a regional system) compliance with the requirements of the revised federal regulations shall be required within nine years of the effective date of the revised federal regulations.

A compliance schedule imposed by the commissioner pursuant to the grant of an exemption shall be enforceable as if it were a rule of the commissioner.

Statutory Authority: *MS s 144.381 to 144.388*

RECORD MAINTENANCE; REPORTING; PUBLIC NOTIFICATION**4720.3600 RECORD MAINTENANCE.**

Subpart 1. **Records to be maintained.** Any owner or operator of a public water supply shall retain on its premises or at a convenient location near the premises, and shall make available for public inspection, the following records for the specified period of time:

A. Records of bacteriological analyses and turbidity measurements made pursuant to parts 4720.1200 and 4720.1300 shall be kept for not less than five years.

B. Records of chemical analyses made pursuant to parts 4720.1400 to 4720.1900 shall be kept for not less than ten years.

Subp. 2. **Laboratory reports.** Actual laboratory reports may be kept, or data may be transferred to tabular summaries, provided that the following information is included:

A. the date, place, and time of sampling, and the name of the person who collected the sample;

B. identification of the sample as to whether it was a routine distribution system sample, check sample, raw or process water sample, or other special purpose sample;

C. date of analysis;

D. laboratory and person responsible for performing analysis;

E. the analytical technique or method used; and

F. the results of the analysis.

Subp. 3. **Records of actions.** Records of action taken by the supply to correct violations of rules dealing with public water supplies shall be kept for a period not less than three years after the last action taken with respect to the particular violation involved.

Subp. 4. **Copies of reports.** Copies of any written reports, summaries, or communications relating to sanitary surveys of the supply conducted by the supply itself, by a private consultant, or by any local, state, or federal agency, shall be kept for a period of not less than ten years after completion of the sanitary survey involved.

Subp. 5. **Records of variance or exceptions.** Records concerning a variance or exemption granted to the supply shall be kept for a period ending not less than five years following the expiration of such variance or exemption.

Statutory Authority: *MS s 144.381 to 144.388*

4720.3700 REPORTING REQUIREMENTS.

Subpart 1. **Results of analysis on sample.** All the results of analyses performed on samples which are to be tested pursuant to these rules shall be reported as follows:

A. The approved laboratory shall submit all analytical results on reporting forms to be prescribed by the commissioner. These forms shall be prepared in triplicate, with one copy being sent to the supplier, one copy being sent to the state Department of Health, Division of Environmental Health, Section of Public Water Supplies, and the third being retained by the laboratory.

B. Results of turbidity and chlorine residual measurements shall be submitted by the supplier on the prescribed reporting forms.

Subp. 2. **Reporting forms.** Except when a shorter reporting period is specified, all results of tests, analyses, or measurements shall be submitted on prescribed reporting forms to the commissioner within the time period specified in item A or B, whichever is shorter:

A. the first ten days following the month in which the result is received by the supplier; or

B. the first ten days following the end of the required monitoring period as stipulated by the commissioner.

Subp. 3. Reporting positive test results. A laboratory performing microbiological analyses pursuant to parts 4720.0100 to 4720.3900 shall report to the supplier and to the commissioner any positive test results within 24 hours of the time the positive result becomes available.

The supplier shall report to the commissioner a positive bacteriological test result within 24 hours of the time the supplier learns of such a result.

Subp. 4. Reporting failure to comply with rules. The supplier of water shall report to the commissioner within 48 hours the failure to comply with any of the rules relating to public water supplies, including the failure to comply with a monitoring requirement, as set forth in parts 4720.1000 to 4720.2500.

Statutory Authority: *MS s 144.381 to 144.388*

4720.3800 RIGHT OF INSPECTION.

The commissioner, or one of its authorized representatives, upon presenting appropriate credentials to any water supplier, is authorized to enter and inspect any establishment, facility, or other property of such supplier, in order to determine whether such supplier has acted or is acting in compliance with the rules of the commissioner relating to water supplies, including for this purpose the inspection of records, files, papers, processes, controls, and facilities, or in order to test any feature of a public water supply, including its raw water source.

Statutory Authority: *MS s 144.381 to 144.388*

4720.3900 PUBLIC NOTIFICATION.

Subpart 1. Notification required. Public notification must be made by a supplier of water whenever a public water supply:

A. fails to comply with a maximum contaminant level prescribed in parts 4720.0400 to 4720.0900;

B. fails to comply with a prescribed monitoring schedule pursuant to parts 4720.1000 to 4720.2500;

C. fails to submit timely reports pursuant to part 4720.3700;

D. is granted a variance or exemption from a maximum contaminant level pursuant to parts 4720.2600 to 4720.3500;

E. fails to comply with a schedule prescribed pursuant to such a variance or exemptions; or

F. fails to comply with an applicable testing method established in parts 4720.1000 to 4720.2500.

Subp. 2. Form of notice. A notice given pursuant to this part shall be written in a manner reasonably designed to inform fully the user of the supply. The notice shall be conspicuous and shall not use unduly technical language, unduly small print, or other methods which would frustrate the purpose of the notice. The notice shall disclose all material facts regarding the subject including the nature of the problem and, where appropriate, a clear statement that a rule dealing with public water supplies has been violated, and shall also disclose any preventive measures that should be taken by the public. Where appropriate, or where required by the commissioner, bilingual notice shall be given. Notices may include a reasonable explanation of the subject of the notice and of its significance or seriousness to the public health, a fair explanation of steps taken by the supply to correct any problem, and the results of any additional sampling.

Subp. 3. Notice by community water supply. In the case of a community water supply, the supplier shall give notification as referred to in subparts 1 and 2:

A. By including a notice in the first set of water bills issued after any of the conditions described in subpart 1 occurs.

B. If the supply issues bills less frequently than every three months, or does not issue water bills, the supplier must give notice by direct mail to every residence served, within six weeks after the condition which gave rise to the need for such notice has occurred.

C. In addition, a copy of every notice mailed pursuant to this part shall be sent to the commissioner, as part of the same mailing which is made to the supply's customers.

In the case of a failure to comply with a maximum contaminant level, such written notice shall be repeated according to the procedure prescribed in subpart 3 not less than once every three months after the initial notice. Such continuing notice must be given as long as the failure to comply continues, whether or not the supply has a variance or exemption relating to the maximum contaminant level which is being exceeded.

In the case of a failure to comply with a maximum contaminant level which is not corrected promptly after discovery, the supplier must give other general public notice of the failure, in addition to the notice by direct mail, in a manner to be prescribed by the commissioner. Such additional notice may include announcements to communications media in the area served by the supply.

Subp. 4. Notice by noncommunity water supply. In the case of noncommunity supply, the supplier must give notice by conspicuous posting. Notice must be posted at or near every tap or drinking fountain, or wherever the public can draw the water. If the water is served to the consumer, then additional notice must be posted on the menu, or registration form, or in some other obvious location to assure adequate readability of the notice, before the water is consumed. The commissioner shall order the form and location for the posting of such notice. Such notice must remain posted as long as any one of the conditions cited in subpart 1 continues to exist.

Subp. 5. Commissioner determines imminent risk to public health. Whenever the commissioner determines that a supply is providing water which, if consumed, might create an imminent risk to the public health, the commissioner may order the supplier to give a notice or warning of such risk in a prescribed manner.

Subp. 6. Commissioner's notice not to relieve supplier of responsibility. The commissioner may issue any notice or warning required by this part on behalf of a supplier, but a supplier is not relieved of any responsibility to issue any notice or warning under this part, unless he has been specifically relieved of the responsibility by the commissioner, in writing.

Statutory Authority: MS s 144.381 to 144.388

4720.3910 TYPHOID FEVER.

Subpart 1. Patient's room. The patient's room shall be carefully screened throughout the course of the disease and during convalescence, if any flies or insects are about.

Subp. 2. Handling milk or other foods. No person convalescent from typhoid fever or paratyphoid fever, or suffering from "walking typhoid," or proven by proper laboratory tests to be a carrier of bacillus typhosus or bacillus paratyphosus, shall be permitted to handle in any capacity milk, cream, butter, other food or food products, liable to be eaten without being cooked after handling, if such foods are offered for sale, until the local health officer, with the approval of the commissioner of health, shall state in writing, with the circumstances indicated, that danger of infection from such person no longer exists.

Subp. 3. Water supplies. Any drinking water supply known to be a positive or probable source of typhoid fever or other disease, shall be condemned either by the local board of health or by the commissioner of health, and when so condemned, shall not be used again as a drinking water supply until declared safe by the condemning party.

Subp. 4. Reporting of cases in hospitals and sanatoria. On discharge from any hospital or sanatorium of any person suffering or convalescent from typhoid fever or paratyphoid fever or of any person known to be a carrier of typhoid organisms or paratyphoid organisms, it shall be the duty of the superintendent of such hospital, or sanatorium to report the discharge in writing to the Division of Disease Prevention and Control of the Minnesota Department of Health within a period of 24 hours, giving the destination of such person.

Statutory Authority: *MS s 144.05; 144.12 subd 1*

History: *L 1977 c 305 s 39; 9 SR 2584*

WATER HAULERS

4720.4000 PURPOSE.

Parts 4720.4000 to 4720.4600 are adopted for the purpose of assuring that sanitary procedures are followed by those who distribute drinking water by tank truck and that the public health is thereby preserved. The authority for adopting parts 4720.4000 to 4720.4600 may be found in Minnesota Statutes 1976, section 144.12, subdivision 1, clause (5) as amended by Laws of Minnesota 1977, chapter 66, section 10 which states that the commissioner of health may regulate the "distribution of water by persons."

Statutory Authority: *MS s 144.12 subd 1; 144.381 to 144.388*

4720.4100 DEFINITIONS.

Subpart 1. Accessible. "Accessible" means capable of being exposed for cleaning and inspection.

Subp. 2. Approved source. "Approved source" means a public water supply which is in compliance with state rules relating to water supplies, and is equipped with a permanent overhead delivery system designed to prevent the introduction of biological or chemical contaminants.

Subp. 3. Commissioner. "Commissioner" means the commissioner of health or his or her authorized representative.

Subp. 4. Corrosion-resistant. "Corrosion-resistant" means capable of maintaining original surface characteristics under the prolonged influence of the use environment, including the expected water contact and normal use of cleaning compounds and sanitizing solutions.

Subp. 5. Easily cleanable. "Easily cleanable" means readily accessible, and of such material and finish and so fabricated that cleaning can be accomplished by hand scrubbing.

Subp. 6. Sanitize. "Sanitize" means the bactericidal treatment of the interior surfaces of the tank by a process which has proven effective and does not leave a toxic residue.

Subp. 7. Smooth. "Smooth" means a surface free of pits and inclusions.

Subp. 8. Toxic. "Toxic" means having an adverse physiological effect on man.

Subp. 9. Water hauler. "Water hauler" or "hauler" means a person engaged in bulk vehicular transportation of water to other than the hauler's household, which is intended for use or used for drinking or domestic purposes.

Statutory Authority: *MS s 144.12 subd 1; 144.381 to 144.388*

4720.4200 WATER HAULER.

A water hauler shall be free of any infectious or communicable disease.

The water hauler shall consult with regional district personnel of the Minnesota Department of Health before implementing any questionable procedures.

Dipping into the filled tank is prohibited.

Statutory Authority: *MS s 144.12 subd 1; 144.381 to 144.388*

4720.4300 TANK REQUIREMENTS.

The tank shall be constructed of stainless steel or be lined with glass or other acceptable, corrosion resistant and nontoxic material, with rounded corners and a smooth surface so that the interior may be thoroughly cleaned and sanitized.

The system shall be completely closed except for vents which are properly constructed and screened.

Caps on inlets and outlets shall be hinged or chained to provide a permanent attachment.

The inlets and outlets shall be easy to clean and so located and protected as to minimize the hazard of contamination.

Filters shall not be used.

The tank shall be filled only from the top.

The outlet hose from the tank shall be maintained in a sanitary condition at all times, shall be flushed clean prior to every delivery, and shall not impart any taste or odor to the water.

The tank shall be accessible internally, for proper cleaning, disinfection, and inspection.

The tank shall never have been used to haul any materials which might have a deleterious effect on health or on the quality of the water being transported. If the tank has been used for transporting any materials other than water, the hauler shall obtain the approval of the commissioner before using the tank to haul water for drinking or domestic use.

Statutory Authority: MS s 144.12 subd 1; 144.381 to 144.388

4720.4400 CLEANING AND DISINFECTION.

The tank and all fittings shall be cleaned and sanitized according to the following procedures before they can be used to haul water, and thereafter once per week: the tank shall be cleaned by scrubbing manually with brushes and noncorrosive detergents, or by automation using a spray ball within the tank which provides cleaning solution with sufficient velocity to remove all soil from the tank interior; the tank and fittings shall then be rinsed.

The tank and fittings shall be sanitized by any of the following methods:

A. filling with water from an approved source to which 50 parts per million chlorine has been added, mixing and allowing it to stand for three to four hours; or 100 parts per million chlorine for not less than 20 minutes; or

B. the commissioner may approve the use of an alternate sanitizing method if the supplier can show that the use of the alternate method assures a level of biocidal activity comparable to that provided by the use of chlorine.

The tank may be cleaned and sanitized in a single step by using a commercial detergent-sanitizer according to the manufacturer's directions.

After sanitizing, the tank shall be drained, and the tank and fittings shall be rinsed with water from an approved source.

The sanitized tank shall be filled with water from an approved source.

The hauler shall add sufficient chlorine to assure that there is one part per million free chlorine residual when the last remaining quantity of water is delivered to a user. The hauler shall test the chlorine residual in each tankful of water using the DPD method.

Statutory Authority: MS s 144.12 subd 1; 144.381 to 144.388

4720.4500 TESTING.

Once each month the hauler shall collect a sample of water from each tank and shall submit the water sample to the state Department of Health laboratory for a bacteriological analysis. Sample collecting bottles for this purpose may be obtained from any Minnesota Department of Health regional district office or by

MINNESOTA RULES 1987

4229

PUBLIC WATER SUPPLIES 4720.5000

writing to the Minnesota Department of Health, Section of Analytical Services, 717 Delaware Street SE, Minneapolis, Minnesota 55440.

Statutory Authority: *MS s 144.12 subd 1; 144.381 to 144.388*

4720.4600 RECORDS.

The hauler shall retain a written log for each tank and shall record therein:

- A. the date when the tank is sanitized;
- B. the date on which the tank is filled and the name of the approved source from which the water is obtained;
- C. the chlorine residual and date on which it is measured;
- D. date on which water samples are sent for analysis; and
- E. customer's name, address, date, and quantity delivered.

Statutory Authority: *MS s 144.12 subd 1; 144.381 to 144.388*

4720.5000 LABORATORY ANALYSIS FEES.

Subpart 1. Fees set by commissioner. The commissioner shall set fees for analysis of water samples by the department's environmental health laboratory.

MINNESOTA RULES 1987

Utility Contract Costs

| Analysis | Cost Per Analysis | Surface Water Source by Population | | | | Ground Water Source by Population | | | | | |
|-------------------------------|-------------------|------------------------------------|-----------------|------------------|------------------|-----------------------------------|-----------------|---------------------------------------|-----------------|------------------|-----------------|
| | | less than 10,000 | | 10,000 & greater | | 1,000 or less | | greater than 1,000 & less than 10,000 | | 10,000 & greater | |
| | | Frequency | 45-Month Cost | Frequency | 45-Month Cost | Frequency | 45-Month Cost | Frequency | 45-Month Cost | Frequency | 45-Month Cost |
| total coliform | \$ 9.20* | 1/month | \$414.00 | 1/month | \$ 414.00 | 1/3 mos. | \$138.00 | 1/month | \$414.00 | 1/month | \$414.00 |
| arsenic | 7.60 | | | | | | | | | | |
| barium | 6.30 | | | | | | | | | | |
| cadmium | 5.50 | | | | | | | | | | |
| chromium | 5.50 | | | | | | | | | | |
| flouride | 5.20 | | | | | | | | | | |
| lead | 6.30 | 1/15 mos. | 247.50 | 1/15 mos. | 247.50 | 1/45 mos. | 82.50 | 1/45 mos. | 82.50 | 1/45 mos. | 82.50 |
| mercury | 29.40 | | | | | | | | | | |
| nitrate-Nitrogen | 4.10 | | | | | | | | | | |
| selenium | 7.10 | | | | | | | | | | |
| silver | 5.50 | | | | | | | | | | |
| radio-chemicals | 97.00** | 1/45 mos. | 96.99 | 1/45 mos. | 96.99 | 1/45 mos. | 96.99 | 1/45 mos. | 96.99 | 1/45 mos. | 96.99 |
| organics | 72.30 | | | 1/3 mos. | 1084.50 | | | | | 1/15 mos. | 216.90 |
| TOTAL | | | \$758.49 | | \$1842.99 | | \$317.49 | | \$593.49 | | \$810.39 |
| Payment Due Every 15 months = | | | \$252.83 | | \$ 614.33 | | \$105.83 | | \$197.83 | | \$270.13 |

*No charge for resampling

**Includes alpha, uranium and prorated radium -226 and -228

| | | | | | |
|--|-----------|-----------|------------|------------|-----------|
| Number of utilities in each category | 16 | 8 | 700 | 240 | 35 |
| Estimated revenue from each category/15 mos. | \$4045.28 | \$4914.64 | \$74081.00 | \$47479.20 | \$9454.55 |

Subp. 2. Mandatory analyses fees. The following fees are for the mandatory analyses of water samples in compliance with the Minnesota Safe Drinking Water Act, Minnesota Statutes, sections 144.381 to 144.387.

4720.5000 PUBLIC WATER SUPPLIES

4230

MINNESOTA RULES 1987

4231

PUBLIC WATER SUPPLIES 4720.5000

Subp. 3. **Optional analyses fees.** The following fees are for the optional analyses performed by the department's environmental health laboratory.

Group A

| | |
|--------------|---------|
| Total Solids | \$ 9.70 |
| Turbidity | 4.50 |
| Color | 2.50 |
| pH | 3.20 |
| Chloride | 6.40 |
| Sulfate | 9.70 |
| Potassium | 5.50 |
| | <hr/> |
| Total Cost | \$41.50 |

Group D

| | |
|------------|---------|
| Iron | \$ 4.30 |
| Manganese | 4.30 |
| | <hr/> |
| Total Cost | \$ 8.60 |

Group E

| | |
|--------------------------------|-----------|
| Total Hardness | no charge |
| Alkalinity | \$ 6.40 |
| Calcium as CaCO ₃ | 4.60 |
| Magnesium as CaCO ₃ | 5.10 |
| | <hr/> |
| Total Cost | \$16.10 |

Total Coliform \$ 9.20

Statutory Authority: *MS s 16A.128*