

**1303.2320 WINDOW FALL PREVENTION REQUIRED.**

Windows that are required to comply with part 1303.2310 must be equipped with window fall prevention screens, guards, or other devices that comply with ASTM F 2006 or ASTM F 2090.

**Exceptions:**

1. Fixed, nonoperable windows.
2. Windows located in basements.
3. Windows located below the first story above grade plane.
4. Windows in which the opening of a window in any position does not permit a four-inch diameter sphere to pass through the opening.
5. Windows in which the bottom of the sill is more than 24 inches (610 mm) above the finished floor.

**Statutory Authority:** *MS s 326B.02; 326B.101; 326B.106; 326B.13*

**History:** *33 SR 1859*

**Published Electronically:** *July 1, 2009*