

1305.1015 SECTION 1015, EXIT AND EXIT ACCESS DOORWAYS.

IBC section 1015.1 is amended to read as follows:

1015.1 Exit or exit access doorways required from spaces. Two exits or exit access doorways from any space shall be provided where one of the following conditions exists:

1. The occupant load of the space exceeds the values in Table 1015.1.

Exceptions:

- (a) In Groups R-2 and R-3 occupancies, one means of egress is permitted within and from individual dwelling units with a maximum occupant load of 20 where the dwelling unit is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2.
 - (b) Care suites in Group I-2 occupancies complying with Section 407.4.3.
2. The common path of egress travel exceeds the limitations of Section 1014.3.
 3. Where required by sections 1015.3, 1015.4, 1015.5, and 1015.6.
 4. When located in buildings used for educational purposes, laboratories and prep rooms that exceed 500 square feet in area and contain hazardous materials.

Where a building contains mixed occupancies, each individual occupancy shall comply with the applicable requirements for that occupancy. Where applicable, cumulative occupant loads from adjacent occupancies shall be considered in accordance with the provisions of Section 1004.1.

[Table 1015.1 is unchanged.]

Statutory Authority: *MS s 16B.37; 16B.59 to 16B.76; 326B.02; 326B.101 to 326B.194*

History: *32 SR 7; L 2007 c 140 art 4 s 61; art 13 s 4; L 2008 c 337 s 64; 39 SR 1605*

Published Electronically: *June 19, 2015*