

**1306.0040 STANDARD.**

Automatic sprinkler systems must comply with the applicable standard referenced in the State Building Code. If a public water supply is not available, the building official and fire chief shall approve the use of an alternate on-site source of water if the alternate source provides protection that is comparable to that provided by a public water supply. If an adequate alternate water supply sufficient for hose stream requirements is provided or available, the building official and fire chief may permit the water supply requirements for the hose stream demands to be modified.

**Statutory Authority:** *MS s 16B.59; 16B.61; 16B.64; 326B.101; 326B.106; 326B.13*

**History:** *27 SR 1479; L 2007 c 140 art 4 s 61; art 13 s 4*

**Published Electronically:** *July 11, 2007*