

**1309.0315** [Repealed, 32 SR 12]

**1309.0315 SECTION R315, CARBON MONOXIDE ALARMS.**

IRC section R315.1, Carbon monoxide alarms, is amended to read as follows:

**R315.1 Carbon monoxide alarms.** For new construction, every one-family dwelling unit, two-family dwelling unit, and each townhouse dwelling unit shall have an approved and operational carbon monoxide alarm installed when one of the following conditions occur:

1. Fuel-fired appliances are installed; or
2. Have attached garages.

**R315.1.1 Installation.** Carbon monoxide alarms shall be installed outside and not more than 10 feet from each separate sleeping area or bedroom. Alarms shall be installed on each level containing sleeping areas or bedrooms.

**Statutory Authority:** *MS s 326B.02; 326B.101; 326B.106*

**History:** *39 SR 91*

**Published Electronically:** *January 26, 2015*