

1311.0407 SECTION 407, FIRE SUPPRESSION SYSTEMS.

GREB Section 407.1 is amended to read as follows:

407.1 All work areas in any building or portion of a building that is required to have a fire-extinguishing system in accordance with the Minnesota Rules, chapters 1305 and 1306, if specifically adopted by the jurisdiction, shall be provided with an automatic fire-suppression system.

Exception: In other than high-rise structures, where an automatic water supply for sprinkler protection is not available at that floor level, the building official shall be permitted to accept alternative protection.

Statutory Authority: *MS s 16B.59; 16B.61; 16B.64; 326B.101; 326B.106; 326B.13*

History: *27 SR 1479; L 2007 c 140 art 4 s 61; art 13 s 4*

Published Electronically: *February 23, 2009*