

1311.0408 SECTION 408, FIRE ALARMS.

Subpart 1. **Section 408.1.1.** GREB Section 408.1.1 is modified to read as follows:

408.1.1 In Use Groups R-1 and R-2, individual guestrooms and individual dwelling units in any work area shall be provided with smoke detectors complying with Sections 907.2.10.1 and 907.2.10.1.2 of the International Building Code adopted according to Minnesota Rules, chapter 1305.

Exception: Smoke detectors are not required when the work is not occurring within an individual guestroom or individual dwelling unit.

Subp. 2. **Section 408.1.2.** GREB Section 408.1.2 is modified to read as follows:

408.1.2 Where the work area is in Use Group R-3 or R-4, smoke detectors complying with Section 907.2.10.1.2 of the International Building Code adopted according to Minnesota Rules, chapter 1305, shall be provided. When the work area is in any attached dwelling unit in Use Group R-3 or R-4, the requirement is only applicable to a dwelling unit that is part of the work area.

Statutory Authority: *MS s 16B.59; 16B.61; 16B.64; 326B.101; 326B.106; 326B.13*

History: *27 SR 1479; L 2007 c 140 art 4 s 61; art 13 s 4*

Published Electronically: *February 23, 2009*