1311.0503 SECTION 503, ENCLOSURE OF VERTICAL SHAFTS.

Subpart 1. Section 503.2. GREB Section 503.2, Exception 2, is amended as follows:

- 2. In other than Group I occupancies, unenclosed existing stairways need not be enclosed in a continuous vertical shaft when the entire building is provided with an approved automatic sprinkler system and the number of open floors do not exceed three.
- Subp. 2. **Section 503.3.** GREB Section 503.3 and Exception are deleted in their entirety.

Subp. 3. Section 503.4. GREB Section 503.4 is renumbered as new Section 503.3.

Statutory Authority: MS s 16B.59; 16B.61; 16B.64; 326B.101; 326B.106; 326B.13

History: 27 SR 1479; L 2007 c 140 art 4 s 61; art 13 s 4

Published Electronically: February 23, 2009