

**1311.1006 SECTION 1006, STRUCTURAL.**

The exception to IEBC section 1006.1 is amended to read as follows:

**Exception:** Structural elements whose demand-capacity ratio considering the change of occupancy is not more than 105 percent of the demand-capacity ratio based on previously approved live loads. The evaluation of demand-capacity ratios and calculation of design gravity loads, forces, and capacities shall account for the cumulative effects of additions and alterations since original construction.

**Statutory Authority:** *MS s 326B.02; 326B.101; 326B.106*

**History:** *44 SR 487*

**Published Electronically:** *March 31, 2020*