

1311.1011 SECTION 1011, CHANGE OF OCCUPANCY CLASSIFICATION.

Subpart 1. **Section 1011.1.1 Compliance with chapter 9.** IEBC section 1011.1.1 is amended to read as follows:

1011.1.1 Compliance with chapter 9. The requirements of IEBC chapter 9 shall be applicable throughout the building for the new occupancy classification based on the separation conditions in sections 1011.1.1.1 and 1011.1.1.2.

(IEBC subsections 1011.1.1.1 and 1011.1.1.2 remain unchanged.)

Subp. 2. **Section 1011.2.1 Fire sprinkler system.** IEBC section 1011.2.1 is amended to read as follows:

1011.2.1 Fire sprinkler system. Where a change in occupancy classification occurs that requires an automatic fire sprinkler system to be provided based on the new occupancy in accordance with Minnesota Rules, chapter 1305, such system shall be provided throughout the area where the change of occupancy occurs.

Statutory Authority: *MS s 326B.02; 326B.101; 326B.106*

History: *39 SR 95; 44 SR 487*

Published Electronically: *March 31, 2020*