

**1323.0408 SYSTEM COMMISSIONING.**

Subpart 1. **IECC section C408.2.** IECC section C408.2 is amended to read as follows:

**C408.2 Mechanical systems and service water heating systems commissioning and completion requirements.** Prior to the final mechanical and plumbing inspections, the registered design professional, the permit applicant, or an approved agency shall provide evidence of mechanical systems commissioning and completion in accordance with the provisions of this Section.

Construction document notes or specifications shall clearly indicate provisions for commissioning and completion requirements in accordance with this Section and are permitted to refer to specifications for further requirements. Copies of all documentation shall be given to the owner or the owner's authorized agent and made available to the code official upon request in accordance with Sections C408.2.4 and C408.2.5.

**Exception:** The following systems are exempt from the commissioning requirements:

1. Mechanical systems in buildings where the total mechanical equipment capacity is less than 480,000 Btu/h (140 690 W) cooling capacity and 600,000 Btu/h (175 860 W) heating capacity.
2. Systems included in Section C403.5 that serve dwelling units and sleeping units in hotels, motels, boarding houses, or similar units.

(Subsections C408.2.1 through C408.2.5.2 remain unchanged.)

Subp. 2. [Repealed, 44 SR 763]

**Statutory Authority:** *MS s 326B.02; 326B.101; 326B.106*

**History:** *39 SR 1616; 44 SR 763*

**Published Electronically:** *April 1, 2020*