1323.0642 SECTION 6.4.2, LOAD CALCULATIONS.

ASHRAE Standard 90.1, Section 6.4.2, is deleted and replaced with the following Section 6.4.2 and Table 6.4.2:

- **6.4.2 Load calculations.** Heating and cooling system design loads for the purpose of sizing systems and equipment shall be determined in accordance with Minnesota Mechanical Code, chapter 1346.
 - **6.4.2.1 Outdoor design conditions.** Outdoor design conditions shall be selected from Table 6.4.2.1. Locations not listed in Table 6.4.2.1 shall use those of the listed city with geographical proximity and similar climate conditions as approved by the building official.

TABLE 6.4.2.1 Outdoor Design Conditions

City	Summer Db/Wb °F	Winter Db °F
Aitkin	82/72	-24
Albert Lea	85/72	-15
Alexandria	86/70	-21
Bemidji	84/68	-24
Brainerd	86/71	-20
Cloquet	82/68	-20
Crookston	84/70	-27
Duluth	81/67	-20
Ely	82/68	-29
Eveleth	82/68	-26
Faribault	86/73	-16
Fergus Falls	86/71	-21
Grand Rapids	81/67	-23
Hibbing	82/68	-19
International Falls	83/67	-28
Litchfield	85/71	-18
Little Falls	86/71	-20
Mankato	86/72	-15
Minneapolis/St. Paul	88/72	-15

Montevideo	86/72	-17
Mora	84/70	-21
Morris	84/72	-21
New Ulm	87/73	-15
Owatonna	86/73	-16
Pequot Lakes	84/68	-23
Pipestone	85/73	-15
Redwood Falls	89/73	-17
Rochester	85/72	-17
Roseau	82/70	-29
St. Cloud	86/71	-20
Thief River Falls	82/68	-25
Tofte	75/61	-14
Warroad	83/67	-29
Wheaton	84/71	-20
Willmar	85/71	-20
Winona	88/74	-13
Worthington	84/71	-14

Statutory Authority: MS s 326B.02; 326B.101; 326B.106; 326B.13

History: 33 SR 1473

Published Electronically: June 17, 2009