

1323.0646 SECTION 6.4.6, PROHIBITION OF HEATED COMMERCIAL PARKING FACILITIES.

ASHRAE Standard 90.1, Section 6.4, is amended by adding a section to read:

6.4.6 Prohibition of heated commercial parking facilities. An enclosed structure or portion of an enclosed structure used primarily as a parking garage or ramp for three or more motor vehicles shall not be heated.

Exceptions:

- (a) Parking facilities where a majority of parking spaces are within the same building structure as dwelling unit occupancies.
- (b) Parking facilities used exclusively to house vehicles for public emergency, ambulance, or public utility emergency response.
- (c) Parking facilities that are incidentally heated by building relief or environmental exhaust air, provided that it does not create a safety hazard.

Statutory Authority: *MS s 326B.02; 326B.101; 326B.106; 326B.13*

History: *33 SR 1473*

Published Electronically: *June 17, 2009*