

1323.0871 SECTION 8.7.1, DRAWINGS.

ASHRAE Standard 90.1, Section 8.7.1, is amended to read:

8.7.1 Drawings. Construction documents shall require that within 60 days after the date of system acceptance, record drawings of the actual installation be provided to the building owner or the designated representative of the building owner. Record drawings shall include at a minimum the following information:

- (a) a single-line diagram of the building electrical distribution system; and
- (b) floor plans indicating location and area served for all distribution.

Statutory Authority: *MS s 326B.02; 326B.101; 326B.106; 326B.13*

History: *33 SR 1473*

Published Electronically: *June 17, 2009*