

1323.1132 SECTION 11.3.2, HVAC SYSTEMS.

ASHRAE Standard 90.1, Section 11, Table 11.3.2C, is amended to read:

TABLE 11.3.2C Water Chiller Types.

Individual Chiller Plant Capacity	Electric Chiller Type	Fossil Fuel Chiller Type
≤100 tons	Reciprocating	Double-effect absorption direct/indirect fired or Single-effect absorption using waste heat
>100 tons, <300 tons	Screw	Double-effect absorption, direct fired
≥300 tons	Centrifugal	Double-effect absorption, direct fired

Statutory Authority: *MS s 326B.02; 326B.101; 326B.106; 326B.13*

History: *33 SR 1473*

Published Electronically: *June 17, 2009*