

1346.0510 SECTION 510 HAZARDOUS EXHAUST SYSTEMS.

Subpart 1. **Section 510.1.** IMC Section 510.1 is amended by adding an exception to the end of this section as follows:

Exception: Other than sections 510.4 and 510.7, this section shall not apply to laboratory ventilation systems that comply with NFPA 45-2004.

Subp. 2. [Repealed, 34 SR 537]

Subp. 3. [Repealed, 34 SR 537]

Statutory Authority: *MS s 16B.59; 16B.61; 16B.64; 326B.101; 326B.106; 326B.13*

History: *29 SR 299; L 2007 c 140 art 4 s 61; art 13 s 4; 34 SR 537*

Published Electronically: *October 23, 2009*