

**1346.0701 SECTION 701 GENERAL.**

Subpart 1. **Section 701.4.** IMC Section 701.4 is amended to read as follows:

**701.4 Engineered installations.** Engineered combustion air installations shall provide adequate supply of combustion, ventilation, and dilution air, and shall be approved by the building official.

Subp. 2. **Sections 701.4.1 and 701.4.2.** IMC Sections 701.4.1 and 701.4.2 are deleted.

**Statutory Authority:** *MS s 16B.59; 16B.61; 16B.64; 326B.101; 326B.106; 326B.13*

**History:** *29 SR 299; L 2007 c 140 art 4 s 61; art 13 s 4*

**Published Electronically:** *October 23, 2009*