

1370.0160 REQUIRED EXITS.

Subpart 1. **Exits; openings.** At least two exits must be provided in compliance with chapter 10 of the International Building Code. The second exit from a single purpose storm shelter may have an opening of at least nine square feet with a minimum of 20 inches in width and the bottom of the opening not more than 44 inches from the floor.

Subp. 2. **Disability access.** At least one of the exits must comply with chapter 1341, Minnesota Accessibility Code.

Subp. 3. **Exit to exterior.** When a portion of a structure is designed as a storm shelter, one exit must be directly to the exterior of the building or to an exit system complying with the state building code.

Statutory Authority: *MS s 16B.59 to 16B.75; 326B.02; 326B.101 to 326B.151*

History: *12 SR 2251; 23 SR 2042; L 2005 c 56 s 2; L 2007 c 140 art 4 s 61; art 13 s 4; L 2008 c 337 s 64; 35 SR 1427*

Published Electronically: *March 23, 2011*