

3801.3770 ROUGH-IN INSPECTION OF WIRING TO BE CONCEALED.

Where wiring is to be concealed, the inspector must be notified sufficiently in advance to permit completion of a rough-in inspection before concealment, exclusive of Saturdays, Sundays, and holidays. In the event wiring is concealed before rough-in inspection without adequate notice having been given to the inspector, the person responsible for having enclosed the wiring shall be responsible for all costs resulting from uncovering and replacing the cover material.

Statutory Authority: *MS s 326.241*

History: *14 SR 518*

Published Electronically: *January 21, 2009*