

**4620.3559 APPLICABLE WORK PRACTICES FOR ABATEMENT.**

Any person performing asbestos-related work must ensure compliance with parts 4620.3560 to 4620.3598.

A. Notwithstanding this part, for asbestos-related work involving the enclosure, removal, or encapsulation of asbestos-containing material that is located outside the foundation, curtain walls, or roof of a facility and is above grade, the asbestos contractor must comply with parts 4620.3000 to 4620.3724 except parts 4620.3566; 4620.3567; 4620.3568, subparts 1 to 4; 4620.3569; 4620.3570; 4620.3575, subparts 1 to 8; 4620.3580; 4620.3581; 4620.3585; 4620.3592; 4620.3594; 4620.3596; 4620.3597; and 4620.3598.

B. Notwithstanding this part, in the case of asbestos-related work within a tunnel, as defined in part 4620.3100, subpart 33, the asbestos contractor must:

(1) comply with parts 4620.3000 to 4620.3724 except part 4620.3568, subparts 2 to 4; and

(2) use two layers of six-mil polyethylene sheeting for critical containment barriers when complying with part 4620.3567.

**Statutory Authority:** *MS s 144.05; 326.70 to 326.81*

**History:** *20 SR 2765*

**Published Electronically:** *June 3, 2013*