

4626.0985 5-101.12 SYSTEM FLUSHING AND DISINFECTION.*

A drinking water system shall be flushed and disinfected according to chapters 4714, 4720, and 4725 before being placed in service after construction, repair, or modification and after a flood or other emergency situation that may introduce contamination to the system.

Statutory Authority: *MS s 31.101; 31.11; 144.05; 144.08; 144.12; 157.011*

History: *23 SR 519; 40 SR 71*

Published Electronically: *April 1, 2016*