

4626.1050 HANDWASHING SINK; INSTALLATION. 5-202.12

A. A handwashing sink must be equipped to provide water at a temperature to allow handwashing for at least 15 seconds through a mixing valve or combination faucet.p2

B. A steam mixing valve must not be used at a handwashing sink.

C. A self-closing, slow-closing, or metering faucet must provide a flow of water for at least 15 seconds without the need to reactivate the faucet.

D. An automatic handwashing facility must be installed according to the manufacturer's instructions and specifications.

Statutory Authority: *MS s 31.101; 31.11; 144.05; 144.07; 144.08; 144.12; 157.011*

History: *23 SR 519; 43 SR 295*

Published Electronically: *January 2, 2019*