

**4626.1120 5-205.13 SCHEDULING INSPECTION AND SERVICE FOR WATER TREATMENT DEVICE.**

A. A water treatment device, other than a water softener, shall be scheduled for inspection and service according to the manufacturer's instructions and as necessary to prevent device failure based on local water conditions.

B. A backflow preventer shall be inspected, tested, and maintained according to chapter 4715.

**Statutory Authority:** *MS s 31.101; 31.11; 144.05; 144.08; 144.12; 157.011*

**History:** *23 SR 519*

**Published Electronically:** *October 11, 2007*