

**4626.1180 SEWAGE HOLDING TANK CAPACITY AND DRAINAGE. 5-401.11**

A. A sewage holding tank in a mobile food unit or seasonal temporary food establishment must be:

- (1) sized 15 percent larger in capacity than the water supply tank; and
- (2) sloped to a drain that is 1 inch (25 millimeters) in inner diameter or greater, and equipped with a shut-off valve.

B. The sewage must not be discharged on the ground.

C. The regulatory authority may approve an alternate method for conveying and disposing of sewage from a mobile food unit or seasonal temporary food establishment in lieu of a waste-holding tank. The alternative method of conveying and disposing of sewage must meet the requirements of part 4626.1200.

**Statutory Authority:** *MS s 31.101; 31.11; 144.05; 144.07; 144.08; 144.12; 157.011*

**History:** *23 SR 519; 43 SR 295*

**Published Electronically:** *January 2, 2019*