

4658.5400 HEATING SYSTEM; EXISTING CONSTRUCTION.

The heating system must be capable of maintaining a minimum temperature of 71 degrees Fahrenheit in all resident areas during the heating season.

Statutory Authority: *MS s 144A.04; 144A.08*

History: *21 SR 196*

Published Electronically: *October 11, 2007*