

**4658.5410 MECHANICAL ROOMS; EXISTING CONSTRUCTION.**

Mechanical rooms below grade, located in buildings constructed after 1972, with equipment using liquefied petroleum gas, must have continuous mechanical ventilation providing a pressure which is equal to or greater than atmospheric.

**Statutory Authority:** *MS s 144A.04; 144A.08*

**History:** *21 SR 196*

**Published Electronically:** *October 11, 2007*