

**4660.8340 FILTERS, NEW CONSTRUCTION.**

All outside air introduced into living and service areas of a facility shall be filtered. Return air to central ventilation systems shall be filtered.

**Statutory Authority:** *MS s 144.56; 144A.02 to 144A.08*

**Published Electronically:** *October 11, 2007*