

4665.1600 LIGHTING.

Lighting levels, measured 30 inches above the floor, shall not be less than 20 footcandles for all resident use areas, and not less than five footcandles for exit stairways, mechanical equipment, and storage areas.

Statutory Authority: *MS s 144.56*

Published Electronically: *October 11, 2007*