

**4714.0421 FIXTURES AND FIXTURE FITTINGS FOR PERSONS WITH DISABILITIES.**

UPC section 421.2 is amended to read as follows:

**421.2 Limitation of Hot Water Temperature for Public Lavatories.** Hot water delivered from public-use lavatories shall be limited to a maximum temperature of 110° F (43° C) by a device that is in accordance with ASSE 1070 or CSA B125.3. The water heater thermostat shall not be considered a control for meeting this provision.

**Statutory Authority:** *MS s 326B.43; 326B.435*

**History:** *40 SR 71*

**Published Electronically:** *January 25, 2016*