

**4714.0721 LOCATION.**

UPC Table 721.1 is amended to read as follows:

**TABLE 721.1****Minimum Horizontal Distance Required from Building Sewer (feet)**

Water supply wells	See M.R. Chapter 4725 <sup>1</sup>
Building supply	10 <sup>2</sup>

For SI units: 1 foot = 304.8 mm

**Notes:**

<sup>1</sup> The minimum horizontal setback distance between a building sewer and a water supply well is governed by Minnesota Rules, chapter 4725.

<sup>2</sup> Unless otherwise permitted by the Administrative Authority and when installed in accordance with section 720.

**Statutory Authority:** *MS s 326B.43; 326B.435*

**History:** *40 SR 71*

**Published Electronically:** *January 25, 2016*