

**4715.1100 INTERCEPTORS AND SEPARATORS REQUIRED.**

Interceptors for oil, grease, sand, and other substances harmful or hazardous to the building drainage system shall be provided as stated elsewhere in these rules.

The size, type, and location of each interceptor, and of each separator shall conform to the requirements of this chapter, except that units may be accepted which are engineered and manufactured specifically for the intended function and which are documented by the manufacturer and project design engineer to be properly designed and sized for the specific project, and no waste other than those requiring treatment or separation shall discharge into any interceptor.

**Statutory Authority:** *MS s 16B.62; 326.37 to 326.45; 326B.121; 326B.43 to 326B.49*

**History:** *19 SR 590; L 2007 c 140 art 4 s 61; art 6 s 15; art 13 s 4*

**Published Electronically:** *May 14, 2012*