

**4715.1740 WATER PRESSURE.**

When street main pressure exceeds 80 psi, an approved pressure reducing valve shall be installed in the water service pipe near its entrance to the building to reduce water pressure to 80 psi or lower. Where street water main pressures fluctuate significantly, the building water distribution system shall be so designed for the minimum pressure available.

Whenever water pressure from the street main or other source of supply is insufficient to provide flow pressure at fixture outlets as required under part 4715.1770, a booster pump and pressure tank or other approved means shall be installed on the building water supply system. See part 4715.1810 for installation.

**Statutory Authority:** *MS s 326.37 to 326.45; 326B.43 to 326B.49*

**History:** *L 2007 c 140 art 6 s 15; art 13 s 4; 33 SR 2042*

**Published Electronically:** *May 14, 2012*