

**4715.2570 INDIVIDUAL FIXTURE REVENTING REQUIRED.**

When fixtures other than water closets discharge downstream from a water closet, each fixture connecting downstream shall be individually vented, under provisions set down in this code.

**Statutory Authority:** *MS s 326.37 to 326.45; 326B.43 to 326B.49*

**History:** *L 2007 c 140 art 6 s 15; art 13 s 4*

**Published Electronically:** *May 14, 2012*