

**4725.2185 DISTANCE FROM A BUILDING.**

A minimum horizontal isolation distance of three feet must be maintained between a well or boring and the farthest exterior projection of a building, including the walls, roofs, decks, overhangs, and other permanent structures unless the well or boring is located in a building constructed according to part 4725.2175. A building, deck, or other permanent structure, except a well house, must not be built to enclose a well or boring. The well or boring must be accessible for repair and sealing. Environmental bore holes and monitoring wells are exempt from this subpart if sealed within 72 hours of the time construction begins on the well or boring.

**Statutory Authority:** *MS s 103I.101; 103I.111; 103I.205; 103I.221; 103I.301; 103I.401; 103I.451; 103I.501; 103I.525; 103I.531; 103I.535; 103I.541; 103I.621; 144.05; 144.12; 144.383; 157.04; 157.08; 157.09; 157.13*

**History:** *17 SR 2773; 33 SR 211*

**Published Electronically:** *September 2, 2008*