

4725.4750 LEAD PROHIBITION IN POTABLE WATER-SUPPLY WELLS.

Materials used in construction of a potable water-supply well that contact water must not exceed eight percent lead except that solders and flux must not contain more than 0.2 percent lead.

Statutory Authority: *MS s 103I.101; 103I.111; 103I.205; 103I.221; 103I.301; 103I.401; 103I.451; 103I.501; 103I.525; 103I.531; 103I.535; 103I.541; 103I.621; 144.05; 144.12; 144.383; 157.04; 157.08; 157.09; 157.13*

History: *17 SR 2773; 33 SR 211*

Published Electronically: *September 2, 2008*