

4770.0700 HOURS OF OPERATION; ACCESS.

Subpart 1. **Limiting hours of operation.** The commissioner may limit the hours of operation of a manufacturing facility if there is sufficient cause to believe that limiting the hours of operation protects public safety.

Subp. 2. **Restricted access areas.** A medical cannabis manufacturer must use an electronic controlled access system to limit entrance to all restricted access areas of its manufacturing facility and its distribution facilities.

A. An electronic controlled access system must:

- (1) limit access to authorized individuals;
- (2) track personnel entry and exit times;
- (3) lock down the facility in the event of a security threat;
- (4) store data for retrieval;
- (5) remain operable in the event of power failure; and
- (6) enable remote administration.

B. A medical cannabis manufacturer must immediately submit stored controlled-access-system data to the commissioner upon the commissioner's request.

C. Restricted access areas must be identified with a sign that states: "Do Not Enter – Restricted Access Area – Access Limited to Authorized Personnel Only."

Statutory Authority: *MS s 14.389; 152.25; 152.26*

History: *39 SR 1080*

Published Electronically: *February 20, 2015*