

**4770.1000 ALARM SYSTEM REQUIREMENTS.**

A. A medical cannabis manufacturer must install and maintain a professionally monitored security alarm system that provides intrusion and fire detection of all:

- (1) facility entrances and exits;
- (2) rooms with exterior windows;
- (3) rooms with exterior walls;
- (4) roof hatches;
- (5) skylights; and
- (6) storage rooms.

B. For purposes of this part, a security alarm system means a device or series of devices that summons law enforcement personnel during, or as a result of, an alarm condition. Devices may include:

- (1) hardwired systems and systems interconnected with a radio frequency method such as cellular or private radio signals that emit or transmit a remote or local audio, visual, or electronic signal;
- (2) motion detectors;
- (3) pressure switches;
- (4) a duress alarm;
- (5) a panic alarm;
- (6) a holdup alarm;
- (7) an automatic voice dialer; and
- (8) a failure notification system that provides an audio, text, or visual notification of any failure in the surveillance system.

C. A manufacturer's security alarm system and all devices must continue to operate during a power outage.

D. The commissioner must have the ability to access a medical cannabis manufacturer's security alarm system.

E. The manufacturer's security alarm system must be inspected and all devices tested annually by a qualified alarm vendor.

**Statutory Authority:** *MS s 14.389; 152.25; 152.26*

**History:** *39 SR 1080*

**Published Electronically:** *February 20, 2015*