

5230.0285 CHAPTER II, DESIGN.

Subpart 1. **Parts 1 and 2.** Notwithstanding anything to the contrary in ASME B31.1, the following portions of chapter II of ASME B31.1 are recommended rather than mandatory: Part 1, Conditions and Criteria; and Part 2, Pressure Design of Piping Components. The department shall not enforce compliance with Part 1 or Part 2 of chapter II of ASME B31.1

Subp. 2. **Section 122.5.1.** ASME B31.1, section 122.5.1 is amended by adding the following language at the end:

It is mandatory that a pressure gauge be installed on the low-pressure side of a reducing valve. Where two or more reducing valves are installed in series, a pressure gauge shall be installed on the low-pressure side of each pressure-reducing valve.

Subp. 3. **Section 122.7.** ASME B31.1, section 122.7 and all subsections are deleted.

Subp. 4. **Section 122.8.** ASME B31.1, section 122.8 and all subsections are deleted.

Subp. 5. **Section 122.9.** ASME B31.1, section 122.9 is deleted.

Subp. 6. **Section 122.11.2.** ASME B31.1, section 122.11.2 is amended by adding the following language at the end:

The discharge of a high pressure trap shall not empty into a low-pressure receiver unless first run through a flash tank or there is an ample sized vent so a trap failure could not increase the pressure in low-pressure receiver tank.

Statutory Authority: *MS s 326B.925*

History: *34 SR 145*

Published Electronically: *September 16, 2009*