

**7001.4250 NOTIFICATION REQUIREMENTS FOR FIELD-ERECTED TANKS.**

The notification required for field-erected tanks is as described in items A to C.

A. Except as provided in item B, the permittee shall notify the commissioner, in writing, at least 60 days prior to implementation of any of the following:

- (1) construction or installation of any of the following:
  - (a) a new field-erected aboveground storage tank;
  - (b) a new underground substance transmission line appurtenant to an aboveground storage tank;
  - (c) a new floor in an existing field-erected aboveground storage tank;
  - (d) a secondary containment system for a field-erected aboveground storage tank;
  - (e) a cathodic protection system for a field-erected aboveground storage tank or for an underground line;
  - (f) an internal coating for a field-erected aboveground storage tank; or
  - (g) a release detection system for a field-erected aboveground storage tank.
- (2) relocation of a field-erected aboveground storage tank;
- (3) return to service of a closed field-erected aboveground storage tank;
- (4) deviations from American Petroleum Institute standards 650, 651, 652, and 653, if applicable;
- (5) change of substance stored in tank; or
- (6) deviation from schedules contained in the permit.

B. The permittee need not notify the commissioner of any construction or installation of a type listed in item A which is specifically required by the permit or excluded by the terms and conditions of the permit.

C. The permittee shall obtain the commissioner's written approval prior to placing any new field-erected tank or underground transmission line into service, returning to service any field-erected tank closed at the time of issuance of the permit, or deviating from schedules contained in the permit. The commissioner shall respond, in writing, within 30 days of receipt of the permittee's written request.

**Statutory Authority:** *MS s 115.03*

**History:** 23 SR 883

**Published Electronically:** *July 13, 2009*