

7011.0870 STAGE-ONE VAPOR RECOVERY.

Subpart 1. **Applicability.** The owner or operator of a gasoline service station required to install and operate a stage-one vapor recovery system shall comply with this part.

Subp. 2. **System design.** Stage-one vapor recovery systems must:

A. conform with the requirements of Design Criteria for Stage I Vapor Control Systems - Gasoline Service Stations as incorporated by reference in part 7011.0865;

B. incorporate a submerged fill pipe in each storage tank; and

C. have a vent system that is equipped with a pressure vacuum valve that complies with Vapor Recovery Certification Procedure CP-201, as incorporated by reference in part 7011.0865.

Subp. 3. **System operation and maintenance.**

A. The owner or operator of a gasoline service station with a vapor recovery system shall not accept gasoline without the vapor recovery system properly connected.

B. The owner or operator of a gasoline service station with stage-one vapor recovery shall:

(1) maintain and operate the vapor recovery system in accordance with manufacturer's specifications;

(2) promptly repair any malfunction of the system;

(3) keep on the premises a copy of the manufacturer's operation and maintenance instructions and make these instructions available to the commissioner or an authorized representative of the commissioner on request; and

(4) maintain system monitoring or testing devices in proper working order.

Statutory Authority: *MS s 116.07*

History: *27 SR 1579*

Published Electronically: *February 25, 2008*