

**7011.1310 STANDARDS OF PERFORMANCE FOR NEW SEWAGE SLUDGE INCINERATORS.**

No owner or operator of a new sewage sludge incinerator shall allow to be discharged into the atmosphere from the incinerator any gases that:

- A. contain filterable particulate matter in excess of 0.65 g/kg dry sludge input (1.30 lb/ton dry sludge input); or
- B. exhibit 20 percent opacity or greater.

No owner or operator of a new sewage sludge incinerator shall operate the incinerator unless the incinerator uses auxiliary fuel burners that maintain a minimum temperature of 1,200 degrees Fahrenheit for a minimum retention time of 0.3 second or other method of odor control as approved by the commissioner.

For the purposes of this part, "new sewage sludge incinerator" means a sewage sludge incinerator on which construction, modification, or reconstruction commenced after June 11, 1973.

**Statutory Authority:** *MS s 115.03; 116.07*

**History:** *L 1987 c 186 s 15; 18 SR 614; 22 SR 1237; 41 SR 763*

**Published Electronically:** *January 27, 2017*