

**7080.1850 SEWAGE FLOW DETERMINATION FOR DWELLINGS.**

Subpart 1. **System sizing.** If construction of additional dwellings or bedrooms, the installation of water-using devices, or other factors likely to affect the operation of the ISTS can be reasonably anticipated, the system must be designed to accommodate these factors.

Subp. 2. **Design flow.** The estimated design flow for any dwelling must provide for at least two bedrooms. For multiple or multifamily dwellings, the design flow must be calculated according to part 7081.0120.

**Statutory Authority:** *MS s 115.03; 115.55*

**History:** *32 SR 1347; 35 SR 1353*

**Published Electronically:** *October 10, 2013*