

7080.2440 COLLECTION SYSTEMS.

Collection of greater than 2,500 gallons per day of sewage from multiple buildings or multiple other establishments discharging into an ISTS must be:

- A. according to the Prescriptive Designs and Design Guidance for Advanced Designers, incorporated by reference under part 7080.1550, subpart 2; or
- B. designed by a Minnesota licensed professional engineer.

Statutory Authority: *MS s 115.03; 115.55*

History: *35 SR 1353*

Published Electronically: *October 10, 2013*