

7081.0200 SOIL AND SITE REPORT.

All information required in parts 7081.0150 to 7081.0180 must be submitted for review and approval by the local unit of government prior to final design. The submittal must also contain:

- A. a map of the proposed soil dispersal area, drawn to scale, showing:
 - (1) features with a setback within 150 feet of the system;
 - (2) easements within 50 feet of the system;
 - (3) floodplains, wetlands, and surface waters, within 100 feet of the system;
 - (4) location and elevation of all soil pits, borings, and hydraulic tests; and
 - (5) two-foot contour lines;
- B. dates and weather conditions during the field evaluation;
- C. elevations of the periodically saturated soil or bedrock;
- D. proposed depths of the system bottom;
- E. proposed soil loading rate;
- F. system site boundaries;
- G. anticipated construction-related issues;
- H. name, address, telephone number, and certified statement of the certified individual conducting the site evaluation; and
- I. a narrative explaining any difficulties encountered during the site evaluation, such as, but not limited to, identifying and interpreting soil and landform features, and how the difficulties were resolved.

Statutory Authority: *MS s 115.03; 115.55*

History: *32 SR 1400*

Published Electronically: *March 11, 2011*