

# **7083.4010 TESTING REQUIREMENTS FOR PROPRIETARY TREATMENT PRODUCTS.**

The testing protocols in this part are incorporated by reference under part 7083.4000, subpart 2, item B.

TABLE I

Treatment component/sequence category	Required testing protocol
Category A: Designed to treat sewage with strength typical of a residential source when septic tank effluent is anticipated to be equal to or less than treatment level C (Table III, part 7083.4030)	NSF Residential Wastewater Treatment Systems, Standard 40, or CEN European Standard, EN-12566-3
Category B: Designed to treat high-strength sewage when septic tank effluent is anticipated to be greater than treatment level C (Table III, part 7083.4030), including restaurants, grocery stores, mini-marts, group homes, medical clinics, residences, etc.	EPA/NSF Protocol for the Verification of Wastewater Treatment Technologies, EPA/ETV Protocol for the Verification of Residential Wastewater Treatment Technologies for Nutrient Reduction, or equivalent
Total nitrogen and phosphorus reduction in Categories A and B	EPA Environmental Technology Verification, Protocol for the Verification of Residential Wastewater Treatment Technologies for Nutrient Reduction, or equivalent or NSF Wastewater Treatment Systems - Nitrogen Reduction, Standard 245

**Statutory Authority:** *MS s 115.03; 115.55*

**History:** *32 SR 1420*

**Published Electronically:** *August 29, 2013*